

639

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/NDZ/2024/ 596

Dated:-30/09/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Pragati Filling Station (Indian oil petro pump) at Jawahar Lal Nehru Marg, New Delhi in a building comprised of Ground + 01 upper floor, Ground floor – ATM room, Workshop Manager's Office, Spare Parts Room, Electrical Panel Room, Petrol Pump and First floor – Offices, Toilet, Spare Parts room, was earlier granted FSC by this department vide letter No.F6/DFS/MS/NDZ/2021/444 dated 14/09/2021. Now, the premises was re-inspected by the officers concerned of this department on 17/09/24 in the presence of Sh. Abhinav Jain and found that the said Petrol Pump have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Hazardous Group J for petrol pump only** with effect from ..30/09/2024.. for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ..30/09/2024..at New Delhi by.

(Arul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. M/S Pragati Filling Station, Jawahar Lal Nehru Marg, New Delhi.

Conditions for the validity of fire safety certificate

1. This FSC is only for Petrol Pump.
2. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
3. No trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical/electric spark should be allowed within the premises and its vicinity.
4. 04 nos. of CO2 gas type ISI capacity of 4.5 kg, 02 nos. of ABC stored pressure powder type ISI capacity 05 kg and 01 number of AFFF type ISI capacity 50 ltrs provided should be maintained in proper working order all the time.
5. The working employees at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
6. Overhead electric cable shall not pass across the licensed premises.
7. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building M/S Pragati Filling Station, Jawahar Lal Nehru Marg, New Delhi
2. Type of occupancy:- Hazardous Group J
Ground + 01 upper floor
3. Type of case:- Renewal
4. Details of previous NOC:- No.F6/DFS/MS/NDZ/2021/444 dated 14/09/2021.
5. Fire safety directives No.- N/A
6. Date of inspection:- 17/09/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer From the building side:- Sh. Abhinav Jain (Partner)
9. Year of construction:- 2010
10. Applicant's letter No:- letter no nil dated 13.08.24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	30 mtr. ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	01 ✓	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	1 mtr. ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr. ✓	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	01 Nos. mechanical foam 50 Kg, 01 Nos. ABC 25 kg, 15 Nos. ABC 4.5 Kg	01 Nos. mechanical foam 50 Kg, 01 Nos. ABC 25 kg, 15 Nos. ABC 4.5 Kg ✓	MR
	2) Types	ABC, CO ₂ , mech. foam trolley	ABC, CO ₂ , mech. foam trolley ✓	MR
	3) ISI marking	Required	Provided ✓	
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	MR
	2) Length of hose reel hose	N/A	N/A	N/A
		N/A	N/A	N/A

	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	No Smoking Signage English & Hindi	Required	Provided English & Hindi	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A

	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckets with sand.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Further, The CNG pump is also operating in the same premises but no fire safety certificate is issued for CNG pump by this department.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/NDZ/2021/444 dated 14/09/2021, under rule 35 of the Delhi Fire Service Rules 2010. Accordingly, DFA is prepared and put up for kind perusal/approval and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Name :- Sh. Ravinder Singh
Designation :- ADO (CC)

~~24/09/2021~~

~~24/09/2021~~

C.F.D.

~~25/9/2021~~

~~25/9/21~~

As approved, it is put up for kind perusal and
 Director
 21/9/21