



c 20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2024/CC/ 46

Dated: 03/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Vision IAS (Coaching Centre)** located at **Metro Station Gate No-2, GTB Nagar, Delhi-110009** comprised of **Ground & 03 upper floors**, Ground Level-(Metro Station Entry/Exits), First & Second Floor Coaching Center & Third floor-lying vacant owned/occupied by the **Vision IAS** have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **29.8.2024** in the presence of **Sh. Vishal R Prasad (Center Head)** and that the building/premises is fit for occupancy Class "**Group B Educational (Coaching Centre)**" for **first & second floor only** with effect from**03/10/2024** for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on**03/10/2024**.. at New Delhi

(Atul Garg)
Director

Ph:-011-23414000
etc

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. M/s Vision IAS (Coaching Centre) located at Metro Station Gate No-2, GTB Nagar, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. **This Fire Safety Certificate is valid only for coaching center at first & second floor for educational occupancy only. In case of any violation, this FSC will be treated as null & void.**
2. All the means of escape shall be kept free from any type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/7

INSPECTION REPORT

1. Name & address of the building : M/s Vision IAS (Coaching Centre) at Metro Station Gate No-2, GTB Nagar Delhi-110009.
2. Type of Occupancy : Mixed Occupancy (Assembly, Education & Business)
3. Composition of building : Ground & 03 upper floors **But Coaching Centre running at 1st & 2nd floor only**, ground floor- being used for Metro Station (DMRC) Entry/Exits Gate & 3rd floor- lying vacant
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 29.08.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Vishal R Prasad (Center Head)
10. Year of Construction : 2022
11. Applicant's letter No. : Online e-mail dated 20.08.2024


| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Part-IV Requirements | Provided at site | Remarks MR/NMR |
|--------------|---|--------------------------|-----------------------------|----------------|
| 1 | Access to building. | | | |
| | • Road width | 06m | 06m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits. | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50m | 1.10m to 2.20m & 02m (iron) | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | Provided | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 02 | 02 | MR |
| | e. Width of Corridor | 1.50m | Opening in hall | MR |
| f. Door Size | 1.20m | 1.20m | MR | |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | Required | Natural Ventilation | MR |
| 5 | Fire Extinguishers. | | | |

| | | | | | |
|----|--|------------|--------------|--|-----|
| | <ul style="list-style-type: none"> Total numbers Types ISI marking | 08nos | 20nos | | MR |
| | | ABC/CO2 | ABC- 20 | | MR |
| | | ISI Marked | Provided | | MR |
| 6 | First-Aid Hose Reels. | | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 01 | Provided | | MR |
| | | 30m | Provided | | MR |
| | | 5mm | Provided | | MR |
| 7 | Automatic fire detection and alarming system. | | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | | NA |
| | | NA | NA | | NA |
| | | NA | NA | | NA |
| | | NA | NA | | NA |
| | | NA | NA | | NA |
| 8 | MOEFA | NA | NA | | NA |
| 9 | Public Address System. | NA | NA | | NA |
| 10 | Automatic Sprinkler System. | | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | NA | NA | | NA |
| | | NA | Provided | | NA |
| | | NA | NA | | NA |
| 11 | Internal Hydrants. | | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA | 100mm | | NA |
| | | NA | Provided | | NA |
| | | NA | Provided | | NA |
| 12 | Yard Hydrants. | | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | NA | | NA |
| | | NA | NA | | NA |
| 13 | Pumping Arrangements. | | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump' head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | | | | |
| | | N/A | N/A | | N/A |
| | | N/A | N/A | | N/A |
| | | N/A | N/A | | N/A |
| | | N/A | N/A | | N/A |
| | | N/A | N/A | | N/A |
| | | N/A | N/A | | N/A |
| | | N/A | N/A | | N/A |
| | | N/A | N/A | | N/A |
| | | 450 LPM | 450 LPM Each | | MR |
| | | 40m | 40m | | MR |
| | | Required | Provided | | MR |
| | | Required | Provided | | MR |
| 14 | Captive Water Storage for fire fighting. | | | | |

| | | | | |
|----|--|------------|----------|-----|
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000 LTR | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/CC/195 dated 03.08.2024.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name:-C.L. Meena
 Designation:- Asst. Div. Officer (RN)

DO (NW)

[Signature]
17/09/2024

[Signature]
18/09/2024

[Signature]
18/09/2024

[Signature]
18/09/2024
Director

[Handwritten notes]
where is the copy for metro
P.T.O. 18/9/24

1-11-20
29.2.24...10/20