



No. F6/DFS/MS/School/NDZ/2024/ 985

Dated: 07/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Cosmos Public School** located at **Vasundhara Enclave, Dallupura, Delhi - 110096**, building comprised of basement (Store), ground plus three upper floors only, owned/occupied by **Cosmos Public School** was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/NDZ/2021/796 dated 29/09/2021 (Two blocks, One for Ground floor only & Second for ground plus first floor). Now the school building (basement, ground plus three upper floors) was re-inspected by the officer concerned of this department on 11/09/2024 in presence of Dr. Chhalesh Chand (Principal) & Mr. Prince (PTI) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building**" (**Group - B**) for ground plus three upper floors only with effect from 07/10/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 07/10/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE  
@

**Copy to:-**

1. The Director of Education, Govt. of NCT Delhi, Old Sectt., Delhi-110054.
2. The Principal, Cosmos Public School located at Vasundhara Enclave, Dallupura, Delhi - 110096.

**Conditions for the validity of Fire Safety Certificate**

1. Fire Safety Certificate is valid for ground plus three upper floors only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. At the time of inspection basement is being for store purpose only.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

4/16

**INSPECTION REPORT**

1	Name & address of the building	Cosmos Public School located at Vasundhara Enclave, Dallupura, Delhi - 110096.			
2	Building is comprised of	Basement (Store), Ground plus three floors only.			
3	Type of occupancy	Educational Building			
4	Type of case	Addition/ Alteration			
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/796 dated 29/09/2021. (Two blocks, first Ground floor only & second ground plus first floor)			
6	Fire safety directives letter no.	NBC Part - IV			
7	Date of inspection	11.09.2024.			
8	Name of the inspecting officers	Yashwant Singh Meena, ADO (Laxmi Nagar)			
9	Name of the designation of officer from the building side	Dr. Chhalesh Chand (Chairman) & Mr. Prince (PTI)			
10	Year of construction	1994 & 2019			
11	Applicant's letter no.	Outdoor Diary No. 6146 dated 06/09/2024			
S. No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR	
1	<b>Access to Building:</b>				
	A	Road width	06 mtrs.	18 mtrs.	MR
	B	Gate width	4.5 mtrs	4.5 mtrs	MR
	C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>				
	A	Number of staircases			
	a	Upper floor	02 nos.	02 nos.	MR
	c	Basement	02 nos.	02 nos.	MR
	B	Width of staircases			
	a	Upper floor	1.50 meters each	1.50 meters each	MR
	b	Basement	1.50 meters each	1.50 meters each	MR
	C	Protection of exits			
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	01 no.	02 nos.	MR
	E	Width of corridor			
	F	Door size	1.50 meters. 1.20 meter	1.84 meters. 1.20 meter	MR MR
3	<b>Compartmentation:</b>				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A

W

N/17

Cosmos Public School located at Vasundhara Enclave, Dallupura, Delhi-110096.

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	18 nos.	25 nos.	MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	<b>C</b>	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	01 no.	01 no.	MR
	<b>B</b>	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	<b>C</b>	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	N/A	N/A	N/A
	<b>B</b>	Location of main panel	N/A	N/A	N/A
	<b>C</b>	Location of repeater panel	N/A	N/A	N/A
	<b>D</b>	Alternate source of power	N/A	N/A	N/A
	<b>E</b>	Hooters	N/A	N/A	N/A
<b>8</b>	<b>MOEFA:</b>		N/A	Provided	MR
<b>9</b>	<b>Public Address System:</b>		N/A	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	N/A	N/A	N/A
	<b>B</b>	Upper floor	N/A	N/A	N/A
	<b>C</b>	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	N/A	Provided	MR
	<b>B</b>	Number of hydrants per floor	N/A	Provided	MR
	<b>C</b>	Hose box	N/A	Provided	MR
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	N/A	N/A	N/A
	<b>B</b>	Hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping Arrangements:</b>				
<b>1</b>	<b>Ground level</b>				
	<b>A</b>	Discharge of main pump	N/A	N/A	N/A
	<b>B</b>	Head of main pump	N/A	N/A	N/A
	<b>C</b>	Number of main pumps	N/A	N/A	N/A
	<b>D</b>	Jockey pump out put	N/A	N/A	N/A
	<b>E</b>	Jockey pump head	N/A	N/A	N/A
	<b>F</b>	Standby pump out put	N/A	N/A	N/A
	<b>G</b>	Standby pump head	N/A	N/A	N/A
	<b>H</b>	Auto starting /manual stopping	N/A	N/A	N/A
	<b>I</b>	Pump house access	N/A	N/A	N/A
<b>2</b>	<b>Terrace Level</b>				
	<b>A</b>	Discharge of pump	900 LPM	900 LPM	MR
	<b>B</b>	Head of the pump	40 mtrs	40 mtrs	MR
	<b>C</b>	Power supply	Required	Provided	MR
	<b>D</b>	Auto starting of pump	Required	Provided	MR

③

✓


**Cosmos Public School located at Vasundhara Enclave, Dallupura, Delhi - 110096.**


<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	15,000 liters	15,000 liters	MR
<b>15 Exit Signage:</b>		Required	Provided	MR
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17 Standby Power Supply:</b>				
<b>18 Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19 Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>		N/A	N/A	N/A


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections and basement is being used for store purpose only.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/NDZ/2021/796 dated 29/09/2021 (Two blocks, One for Ground floor only & Second for ground plus first floor) under the NBC Part IV is recommended to be renewed.

No file is pending with me before disposal of this case.

  
 Signature of the Inspecting Officer  
 Name: - Yashwant Singh Meena  
 Designation: - ADO (L.N)

DY.CFO/NDZ   
 27/09/24


C.F.O.   
 or 10/10/2024

Director 



Sir. F.T Letter is put up for sign. Please

Director   
 24/9/24

  
 3/10/2024