

c36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2024/ 995

Dated: 08/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Govt. Co-Ed. Sr. Sec. School, Located at Pochanpur, Sector-23, New Delhi-110077, having three blocks comprised of (BL-A= Ground floor, BL-B= G + 01 UF & BL-C= G + 03UF), was issued FSC vide Letter No. F6/DFS/MS/School/2021/SZ/208, dated 11/03/2021. The premises was re inspected by the officers concerned of this department on 25/09/2024 in the presence of Ms. Keerti Yadav (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Act 2007 & Rule, 2010 and that the premises is fit for occupancy class "Educational" with effect from 08/10/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...08/10/2024... at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service  
08/10/2024

Copy to:

1. The Principal, Govt. Co-Ed. Sr. Sec. School, Located at Pochanpur, Sector-23, New Delhi-110077.
2. The, Directorate of Education Old Secretariat Delhi - 110054.

**Condition for the validity of fire safety certificate:-**

1. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/27

**INSPECTION REPORT**

1. Name & address of the building: Govt. Co-Ed. Sr. Sec. School, Located at Pochanpur, Sector-23, New Delhi-110077.
2. Type of Occupancy : Educational 3 Blocks, (BL-A= Ground floor, BL-B= Ground + One Upper Floor & BL-C= Ground + Three Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/SZ/208, dated 11/03/21
5. Fire Safety directives Letter No. : NBC of India /UBBL-2016
6. Date of inspection : 25-09-2024
7. Name of the Inspecting Officer : Udai vir Singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Keerti Yadav (Principal)
9. Year of Construction : 2000, 2014 & 2017
10. Applicant's letter No. : Form J Dated nil

No. of Students=1473
No. of class rooms= 54
Plot area=19440 sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/19, N/20 & N/21	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	4.5 mtr	MR(Old Case)
	• Gate width	4.5mtrs	05 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	BL-B=1 BL-C=2	BL-B=1 BL-C=3	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	BL-B=1x150cm BL-C=3x175cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One	MR
	e. Width Of Corridor	150cm	BL-B & C=170cm	MR
	f. Door Size	1m & 1.20m	BL-A&B=1m BL-C=116cm	MR Old case
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA	NA	NA
		12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	25 Nos. ABC & CO <sub>2</sub> ISI marked	42 Nos. Provided ABC & CO <sub>2</sub> ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One each floor	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements: For BL-C= (G+3UF)			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

N/29

14.	Captive water Storage for fire fighting: For BL-C= (G+3UF)			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	10,000 ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the Rules the FSC issued vide letter F6/DFS/MS/School/2021/SZ/208, dated 11/03/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~  
 Name Uday Vire Singh  
 Designation ADP/DW/4

~~DO/SO~~  
~~CFD/SZ~~  
~~Director~~  
11/19/20

ADP/10