

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No. F.6/DFS/MS/School/2024/SZ/980

Dated: 07/10/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Girls Sr. Sec. School located at Goela Khurd, New Delhi- 110071, comprised of two blocks namely New block (Ground plus three upper floors) & Old block (Ground plus one upper floor), was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/1041 dt. 21.12.2021 (for new blk) & F.6/DFS/MS/School/2020/SZ/476 dt. 05.11.2020 (for old blk). The School building was re-inspected by the officer concerned of this department on dated 24.09.2024 in the presence of Mrs. Neha Jain (HOS) and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. 07/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 07/10/2024 at New Delhi by.


 (Atal Garg)
 Director
 Delhi Fire Service

Copy to: -

1. The HOS, Govt. Girls Sr. Sec. School located at Goela Khurd, New Delhi- 110071.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/22

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sr. Sec. School, Goela Khurd, New Delhi- 110071.
2. Building is comprised of : 02 blocks New block (G+3 upper floors) & Old block (G+1).
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2021/SZ/1041 dt. 21.12.2021 (for new blk)
F.6/DFS/MS/School/2020/SZ/476 dt. 05.11.2020 (for old blk)
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 24.09.2024
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:
From the building side : Sh. Neha Jain (HOS)
10. Year of Construction : 2019-20
11. Applicant's letter No : Online email Id ggsssgoelakhurd@gmail.com dated 04.09.2024

S.No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m.	Provided	MR
	• Gate width	4.5 m	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos. (new blk) 03 Nos. (old blk)	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 m each	1.80 M each (new blk) 1.45 M each (old blk)	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 No.	02 No.	MR
	e. Width of Corridor	1.50 m.	1.70 m.	MR
	f. Door Size	1.20 m	1.20 m (new blk) 1.05 m (old blk)	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	22 nos.	22 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	IS I marked	ISI marked	MR

for new block			
6	First-aid-Hose Reels.		
	Total numbers of each floor	02 Nos.	Provided
	• Length of hose reel hose	30 m	Provided
	• Nozzle diameter	05mm	Provided
7	Automatic fire detection and alarming system.		
	• Type of detectors	N/A	N/A
	• Location of main panel	N/A	N/A
	• Location of repeater panel	N/A	N/A
	• Alternate source of power	N/A	N/A
	• Hooter's location	N/A	N/A
8	MOEFA	N/A	N/A
9	Public address System.	N/A	N/A
10	Automatic Sprinkler System.		
	• Basement	N/A	N/A
	• upper floor	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A
11	Internal Hydrants		
	• size of riser/down-comer	N/A	N/A
	• Number of hydrants per floor	N/A	N/A
	• Hose Box	N/A	N/A
12	Yard Hydrants.		
	• Total number of hydrants	N/A	N/A
	• Hose Box	N/A	N/A
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main Pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby pump out put	N/A	N/A
	➤ Standby pump Head	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A
	➤ Pump House Access	N/A	N/A
	• Terrace Level		
	➤ Discharge of pump	450 LPM	450 LPM × 2
	➤ Head of the Pump	40 M	40 M
	➤ Power supply	Required	Provided
	➤ Auto Starting of pump	Required	Provided
14	Captive Water Storage for Fire Fighting.		
	• Underground tank capacity	N/A	N/A
	➤ Draw-off connection	N/A	N/A
	➤ Fire service inlet	N/A	N/A
	➤ Access to tank	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltrs
15	Exit Signage.	Required	Provided

N/24

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2021/SZ/1041 dt. 21.12.2021 (for new blk) & F.6/DFS/MS/School/2020/SZ/476 dt. 05.11.2020 (for old blk) renewal under rule, 37 of the Delhi Fire Service Rules, 2010 is recommended.

R.K. Yadav
26/9/2024

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)

[Signature]
30/9/24

CFO (S2)

[Signature]
11/10/24

[Signature]