

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

c46

**NEW DELHI**

No. F6/DFS/MS/School/WZ/2024/972

Dated: 04/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Government Sarvodaya Bal Vidyalaya** located at **Ramesh Nagar, New Delhi-110015**, in a building Comprised of Ground +03 upper floors & old building comprised of two blocks ground + one upper floor each, one block ground + Auditorium, owned/occupied by **Government Sarvodaya Bal Vidyalaya, Ramesh Nagar, New Delhi - 110015**, was issued FSC by this department vide letter No. F6/DFS/MS/School/MN/2021/662 dated 12/08/2021. The premises was re - inspected by the officer concerned by this department on 22/09/2024 in the presence of Sh. Mohammad Saifi (Principal) and found that the fire safety arrangements/equipments provided in the building found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and the building/ premises is fit for occupancy class "**Educational**" (Group -B) with effect from 04/10/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on ... 04/10/2024 at New Delhi.

(Anil Garg)  
Director

1/2  
03/10/2024

Copy to:

1. The Principal, Government Sarvodaya Bal Vidyalaya located at Ramesh nagar, New Delhi-110015, **Email Id-**
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

M/26

## INSPECTION REPORT

1. Name & address of the building	Government Sarvodaya Bal Vidyalaya Ramesh Nagar, New Delhi-110015.
2. Type of Occupancy	Educational
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/MN/2021/662 dated 12/08/2021
5. Fire Safety directives letter No	Nil
6. Date of inspection	22/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Mohammad Saifi (Principal)
9. Year of Construction	2016-17 (As per prev. Insp. report dtd. -19/08/2021)
10. Applicant's letter No.	Outdoor diary no.6052 dated 04/09/2024

**The said school is running in total 03 Blocks ( BLK-1= ground +03 upper floors, BLK-02= Ground+01 upper floor,& BLK-03= Ground & Auditorium)**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010/BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mts	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts each	G+03=3X1.5m, G+1=1X1.5m, G+1= 2X1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5 Mtr.	Provided	MR
	g. Door Size	1.0m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	12 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

M/X

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>			
		NA	NA	NA
9	<b>Public Address System.</b>			
		NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>			
		Required	Provided	MR

h

2/28

M/R  
M/R

Provision of Lifts.					
16	•	Pressurization of Lift Shaft	NA	NA	NA
	•	Pressurization of Lift lobby	NA	NA	NA
	•	Communication In lift Car	NA	NA	NA
	•	Fireman's Grounding Switch	NA	NA	NA
	•	Lift Signage	NA	NA	NA
17	Standby power supply		NA	NA	NA
18	Refuge Area.				
	>	Total Area	NA	NA	NA
	>	Location	NA	NA	NA
19	Fire Control Room				
	•	Detector System Panel	NA	NA	NA
	•	Flow Switch Panel	NA	NA	NA
	•	PA System Panel	NA	NA	NA
	•	Batter backup	NA	NA	NA
	•	Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

281/ADO/MN  
24/09/2024

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/MN/2021/662 dated 12/08/2021, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*(Signature)*  
24/09/2024

*(Signature)*  
24/9/2024

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

*(Signature)*  
26/9

DCFO/...418.../ADP  
Dated 26/09/24

CFO  
27/9/2024

Director  
*(Signature)*

*(Signature)*

Sir, F.T is put up  
for your kind personal & obj. please. 1  
Director  
*(Signature)*  
03/10/2024