



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/School/996

Dated: 08/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Sri Guru Tegh Bahadur Khalsa Boys/Girls Sr. Secondary School Located at Dev, Nagar, Karol Bagh, New Delhi - 110005, comprised of Ground+2 UFs was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2021/SZ/630 dated 24/08/2021. The premises was re inspected by the officer concerned of this department on 20/09/2024 in the presence of Ms. Harjeet Kaur (Principal) All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 08/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/10/2024 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service.  
9/10/24

Copy to:

1. The Principal , Sri Guru Tegh Bahadur Khalsa Boys/Girls Sr. Secondary School Located at Dev, Nagar, Karol Bagh, New Delhi - 110005.
2. Directorate of Education Old Secretariat Delhi – 110054.

**Condition for the validity of fire safety certificate:-**

1. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/20

**INSPECTION REPORT**

1. Name & address of the building: Sri Guru Tegh Bahadur Khalsa Boys/Girls Sr. Secondary School Located at Dev, Nagar, Karol Bagh, New Delhi - 110005.
2. Type of Occupancy : Educational (Ground + 02 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/SZ/630 dated 24/08/21
5. Fire Safety directives Letter No. : . Circular No. 3298-3398, dated 01/03/11
6. Date of inspection : 20/09/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Harjeet Kaur (Principal)
9. Year of Construction : Before 2007
10. Applicant's letter No. : KGD/24-25/76, dated - 09/09/2024

No. of Students=1422  
 No. of class rooms= 17  
 Plot area=2500 sqm  
 Covered area =1872 sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access of building			MR
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5m	provided	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			MR
	• Upper floors	2 Nos.	Provided	NA
	• Basements	NA	NA	
	b. Width of staircases			
	• Upper floors	1.5m or less & 0.75m	1.46m & 1.20m (iron made FF to SF)	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	Required	2.60m	MR
	f. Door Size	Required	1.06m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

*(Handwritten signature)*



1 N/22

14	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/School/2021/SZ/630 dated 24/08/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name Uday Var Singh  
 Designation ADOP/DK

D/SO  
25/9/24

CF/SO  
10/1/2021  
Director

MR