

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2024/ 976

Dated: 04/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the S.S.D. Saraswati Bal Mandir Sr. Sec. School Located at Road No. 70, West Punjabi Bagh, New Delhi, comprised of ground + 03 Upper Floors, owned/occupied by S.S.D. Saraswati Bal Mandir Sr. Sec. School, was issued FSC by this department vide letter No. F6/DFS/MS/School/WZ/632 dated 24/08/2021. The premises was re - inspected by the officer concerned by this department on 20/09/2024 in the presence of Sh. Deepak Kumar and found that the fire safety arrangements/ equipments provided in the building found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with DOE Circular No. 3298-3398 dated 01/03/201/NBC Part-IV and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from ...04/10/24. for a period of three years in accordance with rule 33 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service rules, 2010. Conditions mentioned below.

Issued on ...04/10/2024 at New Delhi.

(Atul Garg)  
Director

Copy to:

1. The Principal, S.S.D. Saraswati Bal Mandir Sr. Sec. School, Located at Road No. 70, West Punjabi Bagh, New Delhi -110026, Email Id- shrisbmbpbagh@gmail.com
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. **Basement shall not be used for any purpose. If it is used FSC shall be null & void automatically.**

17/30  
**INSPECTION REPORT**

1. Name & address of the building	S.S.D. Saraswati Bal Mandir Sr. Sec. School located at Road No. 70, West Punjabi Bagh, New Delhi.
2. Type of Occupancy	Educational (Ground +3 & Basement)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/WZ/632 dated 24/08/2021
5. Fire Safety directives letter No	DOE Circular No. 3298-3398 dated 01/03/2011
6. Date of inspection	20/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side	Sh. Deepak Kumar
9. Year of Construction	1990 (As per previous insp. dated - 02/08/2021)
10. Applicant's letter No.	Email dated 10/09/2024

\* The said is running at Ground + 03 upper floors, in a building comprised of Ground + 03 upper floors & one basement.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	09 m Provided	MR
	• Gate width	Accessible	4.20 m Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	04 Provided	MR
	• Basements	01	Provided	MR
	b. Width of staircases			
	• Upper Floors	1.5 mts each	1X1.50m, 2X1.33m, 1X1.12m, Provided	MR (old case)
	• Basements	1.5 mts	1.12 X1 Provided	MR (old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	20 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>			
		NA	NA	NA
9	<b>Public Address System.</b>			
		NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	2 X 450lpm Provided	NA
	➤ Head of Main pump	NA	40m Provided	NA
	➤ Number of main pumps	NA	01 Provided	NA
	➤ Jockey Pump out put	NA	180lpm Provided	NA
	➤ Jockey pump head	NA	40m Provided	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900lpm	450lpm Provided,	MR (Old case 900lpm provided at GF)
	➤ Head of the pump	Required	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	50,000 ltrs Provided	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>			
		Required	Provided	MR

6 Provision of Lifts.

MR MR IR	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The Fire protection system provided in the building were tested and found functional at the time of inspection. Earlier all the shortcomings issued by this department have been complied by the school management.

Keeping in view deemed compliance of the minimum standards o fire prevention and fire safety requirements under the rules the NOC F6/DFS/MS/School/WZ/632 dated 24/08/2021, renewal under DOE Circular No. 3298-3398 dated 01/03/2011/ NBC Part-IV it is recommended.

3/ADO/MN  
24/09/24

*(Signature)*  
24/09/24

*(Signature)*  
24/9/2024

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADOMN)

CFO/424-ND  
ated. 26/09/24

*(Signature)*  
26/9

CFO  
25/9/2024

Director  
11/9/24

Discharge  
13/10/24  
MS

*(Signature)*  
Sir F.T is setup of  
your kind personal &  
Sij. please.

*(Signature)*  
6/31/2024