



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7.3  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2024/ 984

Dated:- 07/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Sunshine Ideal Public School Located at K-II Block, 50 Feet Road, Nihal Vihar, New Delhi-110041, comprised of Ground + 03 Upper Floors & earlier the School building was comprised of Ground + 01 Upper Floor only and was issued Fire Safety Certificate by this department Vide Letter No. F6/MS/DFS/2008/2214 dated 01/08/2008, owned/occupied by Sunshine Ideal Public School, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and Verified by the officer concerned of Fire Service on 18/09/2024 in the presence of Sh. Sunil Marwaha (Manager) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 07/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 07/10/2024 at New Delhi by.

(Atul Garg)  
Director

Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Sunshine Ideal Public School, K-II Block, 50 Feet Road, Nihal Vihar, New Delhi-110041.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : **Sunshine Ideal Public School Located at K-II Block, 50 Feet Road, Nihal Vihar, New Delhi-110041**
2. Type of Occupancy : Educational
3. Type of Case : New Case/Addition of 2<sup>nd</sup> floor & 3<sup>rd</sup> floor
4. Details of previous NOC : F6/MS/DFS/2008/2214 dated 01/08/2008 (for Ground + 01 Upper Floor only)
5. Fire Safety directives letter No : As per NBC (Part-IV)
6. Date of inspection : 18/09/2024
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of officers from the building side : Sh. Sunil Marwaha (Manager)
9. Year of Construction : 2004 (G+01), 2013 (2<sup>nd</sup> floor) & 2019 (3<sup>rd</sup> floor)
10. Applicant's letter No. : email dated 12/09/2024

The school building is comprised of Ground + 03 Upper Floors only.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02 nos.	04 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 m	0.70 to 0.90 m x 2 (G to 03) 1.5 m x 2 (G to Terrace)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	Provided	MR
	g. Width of Corridor	1.5 m	1.50 to 2.40 m	MR
	h. Door Size	1.0 m (G+01) & 1.2 m (2 <sup>nd</sup> & 3 <sup>rd</sup> )	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A



4	<b>Smoke Management System.</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	08 nos.	09 nos.	MR
	• Types	ABC, CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01 in each floor	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements</b>			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14 Captive Water Storage for fire fighting			
• Underground tank capacity	N/A	N/A	N/A
➤ Draw-off connection	N/A	N/A	N/A
➤ Fire service inlet	N/A	N/A	N/A
➤ Access to tank	N/A	N/A	N/A
• Overhead Tank capacity	10,000 lts	Provided	MR
15 Exit Signage.	Required	Provided	MR
16 Provision of Lifts.			
• Pressurization of Lift Shaft	N/A	N/A	N/A
• Pressurization of Lift lobby	N/A	N/A	N/A
• Communication In lift Car	N/A	N/A	N/A
• Fireman's Grounding Switch	N/A	N/A	N/A
• Lift Signage	N/A	N/A	N/A
17 Standby power supply	N/A	N/A	N/A
18 Refuge Area.			
➤ Total Area	N/A	N/A	N/A
➤ Location	N/A	N/A	N/A
19 Fire Control Room			
• Detector System Panel	N/A	N/A	N/A
• Flow Switch Panel	N/A	N/A	N/A
• PA System Panel	N/A	N/A	N/A
• Batter backup	N/A	N/A	N/A
• Building Floor Plans	N/A	N/A	N/A
20 Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note: - In the reply of the earlier shortcomings issued to vide letter no. F6/DFS/MS/School/WZ/2023/369 dated 31/08/2023, the school management has submitted an affidavit that school falls under non-confirming area, so the school was not approved from MCD.

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire safety Certificate is recommended under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

Accordingly, DFA is put up for approval please.

*Aman Kumar Lathar*  
Aman Kumar Lathar  
ADO (JWP)

*P.F.O.*

*ACFO (JWP)*

*24/9*

*CFO*  
*24/9/2023*  
*Director*  
*25/9/23*

*FOI*  
*426*  
*Date*  
*24/09/2023*