



C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Pet/2024/SZ/ 616

Dated: 07/10/2024

FIRE SAFETY CERTIFICATE

Certified that **M/s Prem Service Station** (Retail outlet of BPCL Petroleum Class A & B) at J.B. Tito Marg, Andrews Ganj, New Delhi-110049, comprised of ground floor only, owned/occupied by M/s Prem Service Station, was issued fire safety certificate by this department vide letter No. F6/DFS/MS/2021/SZ/Pet/472 dated 28/09/2021. The premise was re-inspected by the officer concerned of this department on 25/09/2024 in the presence of Sh. Deepak Naagar (Manager) of the petrol pump and found that said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/ premise is fit for occupancy class "**Mixed**" (Petrol Pump & Service Station) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 07/10/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Authorized Signatory **M/s Prem Service Station** (Retail outlet of BPCL Petroleum Class A & B) at J.B. Tito Marg, Andrews Ganj, New Delhi-110049

Conditions for the validity of Fire Safety Certificate:

1. "No Smoking" and "Not to use Mobile Phone" sign boards should be displayed in such a manner as to be easily readable by all persons.
2. No trade susceptible to cause ignition of petroleum vapor by generating heat, mechanical/ electric spark should be allowed within the premises and its vicinity.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the employee's working at the petrol pump must know the correct method of operation of fire extinguishers/firefighting.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1	Name & Address of the Building	M/s Prem Service Station (Retail outlet of BPCL Petroleum Class A & B) at J.B. Tito Marg, Andrews Ganj, New Delhi-110049		
2	Type of Occupancy	Mixed Occupancy (Petrol Pump & Service Station)		
3	Building Comprised of	Ground floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2021/SZ/Pet/472 Dt. 28/09/2021		
6	Fire Safety Directives Letter No	NBC (Pt-IV)		
7	Date of Inspection	25/09/2024		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Deepak Naagar (Manager)		
10	Year of construction	1965		
11	Applicant letter received through	Outdoor Diary No. 6659 dated 18/09/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required	12 mtr	MR
		NA	NA	NA
		NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	01	01	MR
	➤ Basement.	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	0.90m	0.90m	MR
	➤ Basement	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	NA	NA
	e) Width of corridor	NA	NA	NA
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	Required	2 CO ₂ DCP, ABC & 16 Fire Bucket	MR
		ABC/DCP/CO ₂	Provided	MR
		ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

8

7.	Automatic fire detection & alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground floor.	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump.	NA	NA	NA
	➤ Head of pump.	NA	NA	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection.	NA	NA	NA
	➤ Fire Service Inlet.	NA	NA	NA
	➤ Access to tank.	NA	NA	NA
	• Overhead tank capacity.	NA	NA	NA
15.	No Smoking Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	Provided fire buckets filled with sand., no smoking sign board in Hindi & English and no loose electric wiring seen in premises.		MR

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/2021/SZ/Pet/472 dated 28/09/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S Kumar
07.10.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

CFO (HQ)
13/10/2024
Director

ADO/SJ

Sir,
FT letter is put up for your sig. pl

Director

S Kumar
07.10.24