

c-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2024/ 1032

Dated: 18/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Anglo Sanskrit V. J. Senior Secondary School, Darya Ganj New Delhi-02**, comprised of three blocks: **Main building** (Ground plus one upper floor), **Science Block** (Ground plus one upper floor) & **New Block** (Ground plus one upper floor) was granted Fire Safety Certificate by this department vide letter No.- F6/DFS/MS/School/NDZ/2020/515 dated 25.11.2020. The school building was re-inspected by the officer concerned of this department on 07.10.2024 in the presence of Mr. Gulshan Batra (H.O.S.) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010. The School building having three blocks **Main building** (Ground plus one upper floor), **Science Block** (Ground plus one upper floor) & **New Block** (Ground plus one upper floor) is fit for occupancy (**Group-B**) "**Educational Building**" with effect from18/10/2024.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....18/10/2024.....at New Delhi by.


(Atul Garg)
Director o/c
Delhi Fire Service
Tel:-011-23414000
15/10

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal,
Anglo Sanskrit V.J. Sr. Secondary School, Daryaganj, New Delhi-02.

Conditions for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	Anglo Sanskrit V.J. Sr. Secondary School, Daryaganj New Delhi-02.		
2	Building is comprised of	(School building has divided into 3 blocks) Main Building- (Ground plus one upper floor) Science Block- (Ground plus one upper floor) New Block- (Ground plus one upper floor)		
3	Type of Occupancy	Educational		
4	Type of Case	Renewal (old case)		
5	Details of Previous FSC	F6/DFS/MS/School/NDZ/2020/515 dated 25.11.2020		
6	Fire Safety direction letter No	NA		
7	Date of Inspection	07.10.2024		
8	Name of the Inspecting Officers	Sumit Kumar, ADO (SPM)		
9	Name of the designation of Officer from the building side	Mr. Gulshan Batra (H.O.S.)		
10	Year of Construction	1919		
11	Applicant's letter No	ASVJ/2024 dated 19.09.2024		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As per Education Circular	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	06 m ✓	MR
	Gate width	NA	3.7 m	NA
	Width of internal road	N.A	5.34 m	NA
2	Number, Width, Type and Arrangement of Exits			
	A. Number of Staircases			
	Upper Floor	Main Building - 01 no Science Block- 01 no New. Block -1 no	Main Building -02 nos. Science Block- 02 nos. New. Block -02 nos.	MR
	Basement	NA	NA ✓	NA
	B. Width of Staircases			
	Upper Floor	Main Building - 2 nos. (1.35 m if the staircase less than 1.5 m) Science Block- 1.5 m New. Block -1.5 m	Main Building - 1.35 m & 1.35 m, Science Block- 1.5 m, 1.2 m New. Block -1.5 m, 1.18 m ✓	MR
	Basement	NA	NA	NA
	C. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	D. No. of continuous staircases to terrace	03 nos.	03 nos.	MR
	E. Width of Corridor	1.5 m	2.0 m	MR
	G. Door size	1.0 m	1.0 m	MR
3	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	Basement	NA	NA	NA
	Upper floor	12a/c per hour	Natural	MR

5.	Fire Extinguisher			
	Total numbers	12 nos.	16 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	NA	NA	NA
	➤ Discharge of pump for basement	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA

N
6

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	Total area	NA	NA	NA
	Location	NA	NA	NA
19	Fire Control Room			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The Fire Protection System provided in the school were tested, checked and random and found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/NDZ/School/NDZ/2023/565 dated 29/11/2023 has been rectified.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F6/DFS/MS/School/NDZ/2020/515 dated 25.11.2020 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

Sumit Kumar
09/10/2024

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)
[Signature]
9/10/24
Dy. C.F.O (CDZ)
C.F.O
Director
[Signature]
14/10/2024
[Signature]
[Signature]