

279

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/2024/School/WZ / 1012

Dated: 11/10/2024

FIRE SAFETY CERTIFICATE

Certified that the Building situated at **Bal Bharati Public School, Sector-14, Rohini, Delhi-110085**, comprised of **Basement + Ground + Three upper floors** owned/occupied by **Bal Bharati Public School**, has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2021/School/WZ/650 dated 25.08.2021**. The premises was re-inspected by the officer concerned of this department on **30.09.2024** in the presence of **Mr. Pankaj Ahuja (Account Officer)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have therefore deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy under **Educational "Group B"** with effect from 11/10/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/10/2024 at New Delhi by


(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to :-

1. The Principal, Bal Bharati Public School, Sector-14, Rohini, Delhi-110085.
2. The Director of Education, Old Secretariat, Delhi

OC
my

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	Bal Bharati Public School, Sector-14, Rohini, Delhi-110085.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Basement + Ground + 03 upper floors)			
4. Details of Previous NOC	F.6/DFS/MS/2021/School/WZ/650 dated 25.08.2021.			
5. Fire Safety directives letter No	F.6/DFS/MS/BP/2022/142 dated 29.03.2022.			
6. Date of inspection	03.10.2024			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Pankaj Ahuja (Account Officer)			
9. Year of Construction	1996 & 2022			
10. Applicant's letter No.	OD No.6852 dated 23.09.2024.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03nos.	02 from gr. to terrace & 01 staircase + 01 ramp from gr. to 2 nd floor only	MR
	• Basements	02nos.	03nos.	MR
	b. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	Required	Provided	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	c) Basements	31_/c per hour	Exhaust fan	MR
	d) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	22nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR

Ajay

	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	03nos.	Provided	MR
	• Hose Box	03nos.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	40m	Provided	MR
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	2,00,000ltr	Provided	MR
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	5,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply			

Refuge Area.

> Total Area	-NA-	-NA-	-NA-
> Location	-NA-	-NA-	-NA-
Fire Control Room			
• Detector System Panel	-NA-	-NA-	-NA-
• Flow Switch Panel	-NA-	-NA-	-NA-
• PA System Panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 628 dated 12.09.2024, the FSC issued vide letter no. F.6/DFS/MS/2021/School/WZ/650 dated 25.08.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

[Handwritten Signature]

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

D.B Mukherjee
DO (NW)

[Handwritten Signature]
09/10/2024
by cfo/wz

[Handwritten Signature]
09/10/2024

DCFO/596-NW
Dated: 07-10-24

[Handwritten Signature]
11/10/2024
Director
[Handwritten Signature]
08/10/24

[Handwritten Signature]
ADP/Per

F.I letter is put up for kind perusal and signature please

[Handwritten Signature]
11/10/24
Director

[Handwritten Signature]
10/10/24