

e 36

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

e 37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/EH/WZ/2024/323

Dated: 10/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Cafeteria & Co. (A Unit of Jumbo Restaurants Project Pvt. Ltd.) located at, SH 2F 02A, 2<sup>nd</sup> Floor Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi – 110018 in Pacific Mall is comprised of Two Basements, Ground & four upper floors plus Projection room was issued FSC by this department vide letter no. F.6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023 & FSC issued to Cafeteria & Co. (A Unit of Jumbo Restaurants Project Pvt. Ltd.) vide letter no. F6/DFS/MS/EH/MN/2021/219 dated 09/09/2021. The premises was re inspected by the officer concerned of this department on 30/09/2024 in the presence of Sh. Ashutosh (Manager) and observed that fire prevention and fire safety arrangements provided in the building found in good working condition. The building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D and valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on ....10/10/2024 at New Delhi by.

  
(Atul Garg)  
Director

Copy to:

1. Cafeteria & Co. Unit of Jumbo Restaurants Project ltd. located at, SH 2F, 02A, 2<sup>nd</sup> Floor Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi - 110018.
  2. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027. (dhowest zone@gmail.com)
  3. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. ( addlcp.lic-dl@nic.in.)
- 8/10/24

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

2/10

## INSPECTION REPORT

1. Name & address of the building	Cafeteria & Co. (A Unit of Jumbo Restaurants Project Pvt. Ltd.), located at SH, 2F, 02A, 2 <sup>nd</sup> . Floor, Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi-110018.
2. Type of Occupancy	Assembly (Restaurant)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/MN/2021/219 dated 09/09/2021
5. Fire Safety directives letter No	Nil
6. Date of inspection	30/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Ashutosh (Manager)
9. Year of Construction	2007 (As Per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2024081312625 dated 13/09/2024

**The said restaurant is running at Second Floor in Pacific Mall is comprised of two basement, ground & four upper floors & projection room was issued FSC vide letter no. F.6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	30 mts Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits (common with the mall)</b>			
	a. Number of staircases			
	• Upper Floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1.5m & 2m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	04 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b> (common with the mall)			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	Provided	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	<b>Internal Hydrants</b> (common with the mall)			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements</b> (common with the mall)			
	• Ground Level			
	➤ Discharge of main Pump	NA	Common with the mall	NA
	➤ Head of Main pump	NA	Common with the mall	NA
	➤ Number of main pumps	NA	Common with the mall	NA
	➤ Jockey Pump out put	NA	Common with the mall	NA
	➤ Jockey pump head	NA	Common with the mall	NA
	➤ Standby Pump out put	NA	Common with the mall	NA
	➤ Standby Pump Head	NA	Common with the mall	NA
	➤ Auto Starting/ Manual stopping	NA	Common with the mall	NA
	➤ Pump House Access	NA	Common with the mall	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the mall	MR
	➤ Head of the pump	40 m	Common with the mall	MR
	➤ Power Supply	Required	Common with the mall	MR
	➤ Auto Starting of pump	Required	Common with the mall	MR
14	<b>Captive Water Storage for fire fighting.</b> (common with the mall)			
	• Underground tank capacity	NA	2,00,000 ltrs provided	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20, 000 ltrs	30, 000 Ltrs Provided	MR
15	<b>Exit Signage.</b>	Required	provided	MR

16 Provision of Lifts.				
<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

The fire protection systems provided in the building were checked & found functional at the time of inspection. Earlier All the shortcomings issued by this department have been complied by the restaurant management.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/MN/2021/219 dated 09/09/2021 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

299/ADO/MN  
30/09/2024

~~Dy CPO (u2)~~

~~SPD~~  
30/9/2024

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (Moti Nagar)

Received today (3/10/2024)

~~dy~~ 3/10

DFCO... u/37744  
Date: 3/10/2024

CFO |  
~~U Singh~~  
u/10/2024

~~Director~~  
guy  
4/11/2024

~~ADP/MN~~ Sir, F.T is put up  
for your kind perusal & signature please. 1

~~Director~~  
14/12

~~SPD~~  
08/10/2024

Uploaded  
10/10/24