



e-66

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/ 318

Dated: 09/10/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Haldiram Marketing Private Limited** at Shop No. 31 (GF) & 103 (FF), Multilevel Car Parking cum Commercial Complex, DLF South Square Mall, Sarojini Nagar, New Delhi-110023, comprised of Basement, Ground + Eight Upper Floors but the restaurant at ground and first floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2021/SZ/324 dated 02/11/2021. The premise was re-inspected by the officer concerned of this department on 01/10/2024 in the presence of Sh. Daglesh Kumar (Manager Operations) and observed that the said premise have deemed complied with the fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class "**Assembly Group D**" (Eating House) up to **31/03/2027** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/10/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police (Lic), First Floor, Police Station Defence Colony, New Delhi-110049 (W.r.t online MHA ID: **2024091314230** dated 20/09/2024)
2. Sh. Sanjeev Yadav M/s Haldiram Marketing Private Limited at Shop No. 31 (GF) & 103 (FF), Multilevel Car Parking cum Commercial Complex, DLF South Square Mall, Sarojini Nagar, New Delhi-110023

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/s Haldiram Marketing Private Limited at Shop No. 31 (GF) & 103 (FF), Multilevel Car Parking cum Commercial Complex, DLF South Square, Sarojini Nagar, New Delhi-110023		
2	Type of Occupancy	Assembly "Group D" (Eating House)		
3	Building Comprised of	Basement, Ground + Eight Upper Floors but the Restaurant is at GF & First Floor of the building		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2021/SZ/324 Dt. 02/11/2021		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2008/3507 dated 22/12/2008 & F.6/DFS/MS/BP/2014/17 dated 17/01/2014		
7	Date of Inspection	01/10/2024		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Daglesh Kumar (Manager Operations)		
10	Year of construction	2011		
11	Applicant letter No. /Online MHA	ID No. 2024091314230 dated 20/09/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restt. within Multilevel Car Parking	9m 4.5m 6m from two sides	MR MR MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	03+1 (1 inside the Restt.)	MR
	➤ Basement floor.	NA	N/A	NA
	b) Width of Staircase			
	➤ Upper floors	1.50m	1.50m each	MR
	➤ Basement floor	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	Required	03 Nos	MR
	e) Width of corridor	1.5m/2.0m	Provided	MR
	f) Door size	2m & 1.5m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	NA	NA	NA
	• Fire dampers.	Required	Provided	MR
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floor	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	06 Nos	10 Nos	MR
	• Types	ABC / CO ₂	ABC & CO ₂	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.	Provided and Maintained by Bldg. Mgmt.		
	• Total numbers on each floor.	Two	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

Automatic fire detection & alarming system.				
7	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Smoke & Heat	MR
		Required	Ground Floor	MR
		Control Room	Control Room	MR
		Required	Provided	MR
		Required	Each floor	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System			
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors. Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	150mm	MR
		Required	2 Nos	MR
		Required	2 Nos	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	4 Nos	MR
		Required	4 Nos	MR
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 			
		2280 LPM x 2	2280 LPM x 2	MR
		60m	60m	MR
		Two	Two	MR
		180 LPM	180 LPM	MR
		60m	60m	MR
		2280 LPM	2280 LPM	MR
		60m	60m	MR
		Required	Provided	MR
		Required	Provided	MR
		900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		14	Captive water storage for firefighting.	Common UG & OHS tank for entire complex
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,50,000 Ltrs	1,50,000 Ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		25,000 Ltrs	25,000 Ltrs	MR
		Required	Provided	MR
15	Exit Signage.	Provided and Maintained by Bldg. Mgmt.		
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	NA	as above	NA
		NA	as above	NA
		NA	as above	NA
		NA	as above	NA
		NA	as above	NA
		Required	Provided	MR
17	Standby Power Supply			
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA

19	Fire Control Room.	Provided and Maintained by Bldg. Mgmt.			
		Detector system panel.	NA	Provided	NA
		Flow switch panel.	NA	NA	NA
		PA system panel.	NA	NA	NA
		Battery backup.	NA	Provided	NA
		Building floor plan.	NA	NA	NA
20	Special Fire Protection System for the Protection of special Risk, if any.	Required	CO ₂ flooding system for LT & HT Panel	MR	

The fire protection systems provided in the premises were checked, tested at random and found functional at the of inspection. The main building i.e. Multilevel Car Parking cum Commercial Complex, DLF South Square Mall, Sarojini Nagar, New Delhi has already been issued FSC by this department vide letter No. F6/DFS/MS/Mixed/SZ/2024/131 dated 04/03/2024.

In view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/EH/2021/SZ/324 dated 02/11/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
01.10.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

CFO(HQ)

3 10/2024
Director
01/11/22 *AD/51* *H/P4*

Sir, F.T letter is put up for your sig. pl

Director
you

S. Kumar
07.10.24

Uploaded
10/10/24