

C 34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2024/1034

Dated: 18/10/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Happy English Public School, Located at, RZ -G-13, Nanda Block, Mahavir Enclave, New Delhi - 110045, School is running at ground and first floor in a building comprised of Ground + 02 Upper Floors was issued Fire Safety Certificate vide this department letter No. F6/DFS/MS/2021/524, dated 23/07/2021. The premises was re inspected by the officer concerned of this department on 14/10/2024 in the presence of Ms. Pooja Arora (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance DOE Circular no. 3298-3398 dated 1-3-2011 and that the building is fit for occupancy class B "Educational building" with effect from 18/10/24 for a period of three years. Subject to compliance of the conditions given below.

Issued on 18/10/2024 at New Delhi by.


(Atul Gang)
Director
Delhi Fire Service.
18/10/24

Copy to:

1. The Principal Happy English Public School, RZ -G-13, Nanda Block, Mahavir Enclave, New Delhi - 110045.
2. The, Directorate of Education Old Secretariat Delhi - 110054.

Condition for the validity of fire safety certificate:-

- 1 The Hall seen at 2nd Floor shall not be used for school activities.
- 2 The stairs/ passage shall be kept clear from any obstruction & free from lock & key, as seen during the inspection otherwise the FSC shall be null & void
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 4 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 5 The trained staff should be available round the clock.
- 6 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 7 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 8 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 9 Basement if any shall be used strictly as per building bye laws.
- 10 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/26
INSPECTION REPORT

1. Name & address of the building: Happy English Public School, Located at, RZ -G-13, Nanda Block, Mahavir Enclave, New Delhi - 110045.
2. Type of Occupancy : Educational running at ground and first floor in a building comprised of Ground + 02 Upper Floors
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/2021/524, dated 23/07/2021 (issued to G+1UF Only)
5. Fire Safety directives L. No. : DOE Circular 3298 -3398 Dated 01/03/11.
6. Date of inspection : 14/10/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Ms. Pooja Arora (Principal)
9. Year of Construction : 2010
10. Applicant's letter No. : FSC/HEPS/24 dated 11/09/2024

No. of Students=170
No. of class rooms= 12
Plot area=300yards
Covered area =180 yards

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N3,N4,N5	Provided at site	Remarks																		
1.	Access of building			MR/NMR																		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Accessible</td> <td>Accessible for small fire unit only</td> </tr> <tr> <td>4.5 mtr</td> <td>Directly accessible from road</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> </table>	Accessible	Accessible for small fire unit only	4.5 mtr	Directly accessible from road	NA	NA		MR (Old Case)												
Accessible	Accessible for small fire unit only																					
4.5 mtr	Directly accessible from road																					
NA	NA																					
2.	Number, width, Type & Arrangements of exits																					
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>01 Nos.</td> <td>02 Nos.</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>1.5 mtr If less than 1.5 mtr additional staircase of 0.75 mtr is required</td> <td>0.87 mtr & 1 mtr</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>01</td> <td>Provided</td> </tr> <tr> <td>NA</td> <td>1.45 mtr</td> </tr> <tr> <td>1 mtr</td> <td>01 mtr</td> </tr> </table>	01 Nos.	02 Nos.	NA	NA	1.5 mtr If less than 1.5 mtr additional staircase of 0.75 mtr is required	0.87 mtr & 1 mtr	NA	NA	NA	NA	NA	NA	01	Provided	NA	1.45 mtr	1 mtr	01 mtr		MR
01 Nos.	02 Nos.																					
NA	NA																					
1.5 mtr If less than 1.5 mtr additional staircase of 0.75 mtr is required	0.87 mtr & 1 mtr																					
NA	NA																					
NA	NA																					
NA	NA																					
01	Provided																					
NA	1.45 mtr																					
1 mtr	01 mtr																					
3.	Compartmentation			MR(Old Case)																		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> </tr> </table>	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		NA								
NA	NA																					
NA	NA																					
NA	NA																					
NA	NA																					
NA	NA																					

No. 10

N/27

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	02 nos.each floor	04 Nos.	MR
	• Types	ABC & CO ₂	ABC	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

W128

Captive water Storage for fire fighting:			
• Under ground tank capacity	NA	NA	NA
➤ Draw off connection	NA	NA	NA
➤ Fire service inlet	NA	NA	NA
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	NA	NA	NA
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	NA	NA	NA
➤ Fireman's Grounding Switch	NA	NA	NA
➤ Lift Signage	NA	NA	NA
17. Standby power supply	NA	NA	NA
18. Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/2021/524, dated 23/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note Photographs & affidavit are placed c/30 to c/33.

Signature of the Inspecting Officer.
 Name *Uday Ar Singh*
 Designation. *ADP/Deputy*

ADP(S2)
 16/10/21

CFE(S2)
 16/10/2021
 Director
[Signature]

[Signature]