



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/494

Dated: 31/07/2024

FIRE SAFETY CERTIFICATE

Certified that the **Jawahar Lal Nehru Sports Complex**, Lodhi Road, New Delhi-110003, comprised of Ground + 02 Upper Floors, owned/occupied by Sports Authority of India, has already been issued Fire Safety Certificate by this office vide letter No. F6/DFS/MS/2021/SZ/164 dated 11/03/2021. The premises was re-inspected by the officers concerned of this department on 24/07/2024 in the presence of Mr. SP Bharti (AE/Elect) & Mr. Sailender Thakur (JE/Elect) and observed that the fire prevention and fire safety arrangements provided in the premises are in satisfactory working order. Therefore, the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Assembly**" (Group 'D') (stadium) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/07/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Assistant Engineer (E), Safdarjung Hospital, Sub-Division (E), CPWD, Jawahar Lal Nehru Sports Complex, Lodhi Road, New Delhi-110003
2. Administrator, Jawahar Lal Nehru Sports Complex, Lodhi Road, New Delhi-110003

Conditions for the validity of Fire Safety Certificate:

1. **False Ceiling in specific area where fire incident occurred previously, shall not be installed without prior intimation to this department, as per undertaking submitted, else the FSC shall be withdrawn/suspended.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Jawahar Lal Nehru Sports Complex, Lodhi Road, New Delhi-110003		
2.	Type of Occupancy	Assembly Building (Stadium)		
3.	Building Comprised of	Ground + 02 Upper Floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/2021/SZ/164 dated 11/03/2021		
6.	Fire Safety directives Letter	F6/DFS/MS/StdM/BP/2007/3740 dt. 17/12/2007		
7.	Date of inspection	23/07/2024		
8.	Name of Inspecting Officer	Manoj Kumar Sharma (DO/SD) and Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from building side	Mr. SP Bharti (AE/Elect) & Mr. Sailender Thakur (JE/Elect)		
10.	Year of Construction	1982		
11.	Applicant letter No. / email from ID: ae4sjhed@gmail.com dated 13/07/2024			
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	30m	Provided	MR
	• Gate width	15m	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	28nos + ramps	26nos + 17 ramps (3 inside the stadium)	MR (old case)
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper floors	2 mtr each	1.8m each	MR (old case)
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	Required	14 Nos	MR
	e. Width of Corridor	Required	7.5m	MR
	f. Door Size	Required	1.5m	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke managements System			
	• Basement (Tunnel)	30 ACPH	MV Provided	MR
	• Upper floors	12 ACPH	MV Provided	MR
5.	Fire Extinguishers			
	• Total numbers		220 Nos	MR
	• Types	ISI marked	ABC, CO ₂ & W CO ₂	MR
	• ISI marking		Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor		15 Nos	MR
	• Length of hose reel hose	Hose-reel	30m	MR
	• Nozzle diameter		5mm	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detector Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided (Smoke)	MR
		Required	Ground Floor	MR
		Required	All Floors	MR
		Required	Battery Backup	MR
		Staircase	Provided	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	150 mm	MR
		Required	14 Nos	MR
		Required	14 Nos	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required	42 Nos	MR
		Required	42 Nos	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access 	2280 LPM	Provided	MR
		88m	Provided	MR
		2 Nos	Provided	MR
		180 LPM x 2	Provided	MR
		88m	Provided	MR
		2280 LPM	Provided	MR
		88m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	200,000 Ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	Required	8000 sqm	MR
		Required	2 nd Floor	MR

N-54

19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	-NA-	-NA-	-NA-

Note: - Sh. Nitin Kumar Jaiswal, Administrator, JNS has submitted an undertaking vide letter F. No. SAI/JNS/DFS/2024-25 dated 12.07.2024 that No False Ceiling in the specific area where fire incident had occurred previously shall be installed. Prior to the installation of any false ceiling in that area, intimation shall be provided to this department.

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection. The shortcoming/observation communicated by this department vide even letter no. 432 dated 12/03/2024 found rectified.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/2021/SZ/164 dated 11/03/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj Kumar Sharma
 Signature of the Inspecting Officer
 Name: Manoj Kumar Sharma
 Designation: DO (SD)

Santosh Kumar
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

CFO (HQ)
[Signature]
 26/7/2024

Director
[Signature]
 24/07/24
 ADO (SJ)

Sir,
 F.T letter is put up for your sig. pr
[Signature]
 29/07/24
 MR