



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/1016

Dated: 14/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Lions Vidya Mandir Secondary School, (Behind Kashmir House)**, Kushak Lane, New Delhi-110011, comprised of ground plus two upper floors have already been issued Fire Safety Certificate by this department vide letter No. F6 DFS/MS/School/2016/SZ/790 dated 17/05/2016. The premise was re-inspected by the officer concerned of this department on 03/10/2024 in the presence of Sh. Pradeep Kumar (Vice Principal) and found that the fire safety arrangements provided are in satisfactory working condition. Therefore, said premises/building have deemed complied with the fire prevention and fire safety requirement in accordance with rule Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and that the building is fit for occupancy class **Group-B** (Educational) with effect from 14/10/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/10/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Vice Principal, Lions Vidya Mandir Secondary School, (Behind Kashmir House), Kushak Lane, New Delhi-110011
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Lions Vidya Mandir Secondary School, (Behind Kashmir House), Kushak Lane, New Delhi-110011		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Ground plus two upper floors		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6 DFS/MS/School/2016/SZ/790 dated 17/05/2016		
6.	Fire Safety directives Letter No.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
7.	Date of inspection	03/10/2024		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Pradeep Kumar (Vice Principal)		
10.	Year of Construction	1963		
11.	Applicant's letter No.	LVM/Fire Safety/2024/1509 dated 17/09/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06m	11m	MR
	• Gate width	03m	03m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04nos	05nos + 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	1.60m x 2, 1.20m x 2, 1.08m & ramp-1.22m	MR
	• Basements floor	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02nos	01 stair, 01 ramp	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12nos	27nos	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	100mm	100mm	MR
	• Number of hydrants per floor	02nos	Provided	MR
	• Hose Box	02nos	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM x 2	450 LPM x 2	MR
	➤ Head of the pump	35m	35m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the premises were checked, tested at random and found functional at the time of inspection. The shortcomings communicated by this department vide letter No. F6/DFS/MS/School/SZ/2023/259 dated 18/05/2023 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6 DFS/MS/School/2016/SZ/790 dated 17/05/2016, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S Kumar
07.10.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD) *[Signature]*

Chd (nos)
9/11/24
Director
9/11/24
Am/SJ

Sing
FT letter is put up for your Sing. pl
[Signature]
11/10/24