

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/402

Dated: 09/10/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Maanvi Guest House at 8281, Gali No. 06, Arakashan Road, Pahar Ganj, Delhi in a building comprised of Ground + 05 Upper floors, Ground floor (Reception + 01 office + 02 guest rooms), 1st floor to 3rd floor (05 guest rooms at each floor) total 17 guest rooms up to third floor only with an affidavit not to use any floor above third floor dated 26.09.2021 as submitted by the owner, was earlier granted by this department vide letter No.F6/DFS/MS/GH/NDZ/2021/373 dated 09/09/2021. Now, The premise was re-inspected by the officer concerned of this department on 01/10/24 in the presence of Mr. Nausad and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, Sub Division-A-1 ground floor (01 office , reception , 02 guest room) , 1st to third floor (05 guest room at each floor) total 17 guest rooms only up to 3rd floor and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued09/10/2024...at New Delhi by.

(Atul Singh)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner of North MCD, Civic Centre, New Delhi : to kindly ensure the occupancy in the building as detailed above and deviation in construction if any
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID No 2024091914393 dated 19.09.24.
3. The Manager, M/s Maanvi Guest House at 8281, Gali No. 06, Arakashan Road, Pahar Ganj, Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid for guest house up to third floor only.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as staircase , exits , corridor , etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

19/40
INSPECTION REPORT

1. Name & address of the building M/S Maanvi Guest House at 8281 Gali No. 06, Arakashan Road, Pahar Ganj, Delhi.
2. Type of occupancy:- Residential, Sub Division-A-1
Gr. + 05 Upper floors and room at terrace (total 17 Guest rooms)(Reception , shops, office + 02 guest room), 1st floor to 3rd floor (05 guest room at each level) 4th & 5th floor sealed . and an affidavit dated 26.09.19 regarding not to use any floor above third floor is submitted by owner.
3. Type of case:- Renewal
4. Details of previous FSC:- No.F6/DFS/MS/GH/NDZ/2021/373 dated 09/09/2021.
5. Fire safety directives No.- N/A
6. Date of inspection:- 01/10/2024
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- Mr. Nausad
9. Year of construction:- 1988
10. Applicant's letter No:- ID No 2024091914393 dated 19.09.24. Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	N/A	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			MR
	1. Upper floors	01 No.	01 No.	N/A
	2. Basements	N/A	N/A	
	B. Width of staircase			MR
	1. Upper floors	0.90 mtr.	1.15 mtr. ✓	N/A
	2. Basements	N/A	N/A	
	C. Protection of exits			N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	1.06 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO Type	Required	Provided	MR
	2) Location of main panel	at ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	at each floor	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	25 mtr.	25 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 ltr.	5000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			


W/42



	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: One ABC type fire extinguisher found provided.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2021/373 dated 09/09/2021, under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer


 Name: - Ravinder Singh
 Designation :- ADO (CC)



 4/12/24
 Dy. C.F.O. (2022)
 C.F.O.
 Director
 7/10/2024
