

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

C-38.

No. F6/DFS/MS/School/WZ/2024/1036

Dated: 18/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Mahavira International School**, located at **Ground + 03 upper floors, 1149, Deva Ram Park, Tri Nagar, Delhi-110035**, comprised of basement, Ground and four upper floor (4<sup>th</sup> floor not in use). Owned/Occupied by **Mahavira International School**. The premises was inspected by the officer concerned of this department on 13/09/2024 in the presence of Sh. Smt. Shalini Jain and observed that all the fire prevention and fire safety arrangements provided in the building found in good working condition. The premises have complied with the fire prevention and fire safety requirements in accordance with the DOE circular No. 3298-3398 dated 01/03/2011 and found that the building / premises is fit for the occupancy class "**Educational**" (**Group-B**) with effect from ...18/10/24 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on ...18/10/2024.. at New Delhi.-

(Atul Garg)  
Director  
Delhi Fire Service

**Copy to:**

1. The Principal, Mahavira International School, located at 1149, Deva Ram Park, Tri Nagar, Delhi-110035
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. Basement shall be used as building bylaws.
9. **This NOC is valid for Ground and three upper floors only.**
10. **If owner/occupier used 4<sup>th</sup> floor for any purpose FSC shall be null & void automatically.**

16/10/2024

**INSPECTION REPORT**

1. Name & address of the building	Mahavira International School located at 1149, Deva Ram Park, Tri Nagar, Delhi-110035.
2. Type of Occupancy	Educational (Basement, Ground Plus Four Upper floors, Basement, 4 <sup>th</sup> Floors not in use (School is running on ground and Three upper floors))
3. Type of Case	New Case
4. Details of Previous NOC	Nil
5. Fire Safety Directives letter No	DOE circular No. 3298 -3398 dated 01/03/2011
6. Date of Insepecton	13/09/2024
7. Name of the Inspecting Officers	Sarabjeet, ADO (MN)
8. Name and designation of officers from the building side	Smt. Shalini Jain
9. Year of Construction	1997
10. Applicant's letter No.	Outdoor diary No. 5760 dated 29/08/2024

The Said school is running on Ground and three upper floors, in a building comprised of Basement + Ground + 04 upper floors. 4<sup>th</sup> floor not in use and vacant.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> </ul>	6 m	Provided	MR
	<ul style="list-style-type: none"> <li>Gate width</li> </ul>	4.5m	Directly Accessible	MR
	<ul style="list-style-type: none"> <li>Width of internal road</li> </ul>	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	02	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	1.50 m or not less then 0.75 m	1.10 m & 0.83 m	MR
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	1.10 m & 0.83 m	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Required in basement	Provided	MR
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	NA	NA	NA
	e. No. of continuous staircases to terrace	02	01 Provided	MR
	f. Width of Corridor	Required	Provided	MR
	g. Door Size	1m	1 m including door frame	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Naturally Ventilated	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	10	20	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC Type	Provided	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	Required	Provided	MR

84

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*Signature*

*Signature*  
18/9/2024

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

ADO  
Dated: 18/9/2024

*Signature*  
19/9

Please see the note/condition of FSC at Sl.No. 1069.

*Signature*  
19/9/2024

*Signature*

*Signature*  
put up F.T.

*Signature*  
ADO (MN)

*Signature*  
15/10