

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2024/ 1014

Dated: 11/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **P.M. School** located at B-10, Madhu Vihar, Som Bazar Road, Uttam Nagar, New Delhi-110059, Comprised of ground plus two upper floor owned/occupied P.M School was issued FSC vide letter no. F.6/DFS/MS/school/SZ/2021/322 dated 15.04.2021. The school building was re-inspected by the officer concerned of this department on dated 03.10.2024 in the presence of Sh. Birender Singh, and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**ground plus two upper floors**) is fit for occupancy class "**Educational**" w.e.f. 11/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 11/10/2024 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Principal, P.M. School located at B-10, Madhu Vihar, Som Bazar Road, Uttam Nagar, New Delhi-110059.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : P.M. School at B-10, MadhuVihar, Som Bazar road, Uttam Nagar, New Delhi- 110059.
2. Building is comprised of : **Ground plus Two upper floor**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/SZ/2021/322 dated 15.04.2021
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 03.10.2024
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Sh. Birender Singh
10. Year of Construction : 2012
11. Applicant's letter No : Office outdoor dairy No. 3356 dated 24.06.2024

S. No.	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement UBBL/NBC-IV	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			MR
	Road width	6 mtrs.	06 mtrs.	MR
	Gate width	4.5	Direct accessible from road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	a. Number of Staircases			MR
	Upper Floor	2 nos.	2 nos.	N.A.
	Basement	N.A.	N.A.	
	B. Width of Staircases			MR
	Upper Floor	1.5 m each	1.5 m each	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			N.A.
	Fire check door	N.A.	N.A.	MR
	Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	1.5	1.5 m	MR
g. Width of Corridor	1 m	1 m	MR	
h. Door Size				
3	<b>Compartmentation.</b>			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	<b>Smoke Management System.</b>			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural ventilation	MR

5.	<b>Fire Extinguisher</b>			
	Total numbers types IS marking	12 Nos.	Provided	MR
		CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
		ISI marked	ISI marked	MR
6	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor Length of hose reel hose Nozzle diameter	One	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	<b>MOEFA</b>	N.A.	N.A.	N.A.
9	<b>Public address System.</b>	N.A.	N.A.	N.A.
10	<b>Automatic Sprinkler System.</b>			
	basement upper floor sprinkler above false ceiling	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
11	<b>Internal Hydrants</b>			
	size of riser/down-comer Number of hydrants per floor Hose Box	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
12	<b>Yard Hydrants.</b>			
	Total number of hydrants Hose Box	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
	13	<b>Pumping Arrangements.</b>		
<ul style="list-style-type: none"> <li>• Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main Pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby pump out put</li> <li>➤ Standby pump Head</li> <li>➤ Auto Starting /Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace Level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the Pump</li> <li>➤ Power supply</li> <li>➤ Auto Starting of pump</li> </ul>		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		450 LPM	Provided	MR
		30m	Provided	MR
		Required	Provided	MR
	Required	Provided	MR	
14	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		10,000 ltrs	10,000 ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
				MR

19/24

**Provision of Lifts.**

MR	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
MF	Pressurization of Lift lobby	N.A.	N.A.	N.A.
M	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	<b>Refuge Area.</b>			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	<b>Fire Control Room</b>			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/school/SZ/2021/322 dated 15.04.2021, renewal under rule, 37 of the Delhi Fire Service Rules, 2010 is recommended.

*R.K. Yadav*  
 Signature of Inspecting Officer  
 Name: - R.K. Yadav  
 Designation: - ADO (JKP)

DO (South West) *[Signature]* 8/10/24

CFO (S2) *[Signature]* 8/10/2024

Director *[Signature]*