

2/38

INSPECTION REPORT

1. Name & address of the building	Pulse Restaurant (A unit of Nanak Foods) Located at A-5, First Floor, Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. Type of Occupancy	Class -D (Assembly)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/WZ/2021/239 Dated 22/09/2021
5. Fire Safety directives letter No	F6/6/TMS/Inspection/2004/106 dated 04/04/2005
6. Date of inspection	27/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh (ADO MN)
8. Name and designation of officers from the building side	Deep Kunwar Narang
9. Year of Construction	1980 (As per MHA portal)
10. Online Applicant's ID.	Online application ID- 2024091414279 Dated 14/09/2024

The said restaurant is running at 1st floor in a building comprised at Ground+ Two Upper Floors. Was issued FSC vide Letter no. F6/DFS/MS/EH/WZ/2021/239 Dated 22/09/2021.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 mts 4.5 mts NR	Provided On Main Road NR	MR MR NR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 NA	Provided NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	NR as per 2005 Circular NA	2x 1.15m, 1x 0.89cm NA	MR (Being Old case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA NA	NA NA	NA NA
	e. No. of continuous staircases to terrace	Required	Provided	MR
	f. Width of Corridor	Hall Only	Halls Only	MR
	g. Door Size	Old case	1.20m & 1.02mm	MR (Being Old case)
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA Required	NA Provided	NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 CO ₂ , ABC type ISI marked	Provided Provided Provided	MR MR MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	Provided	NA
		NA	Provided	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		18 lpm & 450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

2/40

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The Fire protection system provided in the building were checked and found functional at the of inspection.

Keeping in view the deemed compliance of the minimum standards on Fire Prevention and Fire safety required under the rules, The NOC issued by this department vide letter no. F6/DFS/MS/EH/WZ/2021/239 Dated 22/09/2021, renewal under rule 35 of the Delhi Fire service rules 2010 is recommended.

Signature
30/9/2021

Signature
30/9/2021

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

UCFOI 419-2222
Date: 30/9/2021

Signature
30/9

CFO
Signature
3/10/2021
Signature
3/9/21

Handwritten notes in Hindi:
एक बात यह बताना है
कि बिजली का काम ठीक है
और फायरिंग सिस्टम भी ठीक है
और बिजली का काम ठीक है
और फायरिंग सिस्टम भी ठीक है

CFO
Signature
4/10/2021
Dy CFO (WZ)

Signature
4/10/2021
ADO (MN)

21/4/1

Sir, necessary correction in Rsc has been done.

R.T is put up for your kind perusal &

~~Director~~
Sir, please.
m

↑
Jt J
10/10/2024

v. Khandal
10/10/24
J.