

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

243
7
आज के दिन
अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2024/ 320

Dated:- 09/10/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Rajbhog Food India, Located at No. 12, Inder Enclave, Main Rohtak Road, New Delhi, is running at ground floor of a building comprised of Basement, Ground, 1st Floor & 2nd Floor only owned/occupied by M/s. Rajbhog Food India, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/2021/WZ/73 Dated 23/03/2021. The said premise was re-inspected by the officer concerned of this department on 01/10/2024 in the presence of Sh. Puneet and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" Group D (Ground Floor only) with effect from 09/10/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 09/10/2024 at New Delhi by.

(Atul Garg)
Director
Tel. No. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. Sh. Vipul Aggarwal, M/s. Rajbhog Food India, No. 12, Inder Enclave, Main Rohtak Road, New Delhi.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The owner of the sweet shop has submitted an affidavit for not to use basement, 1st floor & 2nd floor. If basement or 1st or 2nd floor is used for sweet shop in future FSC will be null & void.

INSPECTION REPORT

1. Name & address of the building : M/s. Rajbhog Food India Located at No. 12, Inder Enclave, Main Rohtak Road, New Delhi-110087
2. Type of Occupancy : Assembly (Restaurant is running at Ground Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2021/WZ/73 dated 23/03/2021
5. Fire Safety directives letter No : NBC (Part-IV)
6. Date of inspection : 01/10/2024
7. Name of the Inspecting Officers : Aman Kumar Lathar. ADO (JWP)
8. Name and designation of officers from the building side : Sh. Puneet
9. Year of Construction : 1998-2000
10. Applicant's online application No. : 2024072211387 dated 23/09/2024

The building is comprised of Basement, Ground, 1st Floor & 2nd Floor only.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ as per FSC dated 04.03.2023	Provided at site	Remarks MR/NMR
1	Access to building	06 mts	Provided	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits	-----	-----	-----
	a. Number of staircases	Running at GF	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	-----	-----	-----
	b. Width of staircases	Running at GF	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	-----	-----	-----
	c. Protection of exits	Required	Provided	MR
	• Fire check door	N/A	N/A	N/A
	• Pressurization	Running at GF	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	02 m & 1.5 m	02 m x 1 & 1.5 m x 1	MR
	h. Door Size	-----	-----	-----
3	Compartmentation.	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.	-----	-----	-----
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A

R.

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	05 nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC, CO ₂ type	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	---	----	-----
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 	----	-----	-----
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power Supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR

Captive Water Storage for fire fighting

	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	
18	Refuge Area.			N/A
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			N/A
	<ul style="list-style-type: none"> Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- The owner of the eating house has submitted an affidavit for not to use basement, 1st floor & 2nd floor for eating house purpose.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2021/WZ/73 dated 23/03/2021 is recommended under Rule 37 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Accordingly DFA is put up for approval please.

DCFO (2021)

DCFO..... 4/16/2021
Date: 4/16/2021

4/10
4/10/2021
Director
4/16/21

Quinta of
04/16/21
Aman Kumar Lathar
ADO (JWP)

ADP
P.F.O

Sir,

F.i. letter is added for your signature M.

Director

[Handwritten signature]

[Handwritten signature]
08/2/24
ADD (wp)

Uploaded
10/10/24
[Handwritten signature]