

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 1043

Dated: 22/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Bachan Parsad Sarvodaya Kanya Vidyalaya** (School ID-1923042) located at Deoli, New Delhi -110080 comprised of A-Block, Ground + 01 upper floor, B-Block Ground plus 02 upper floor, C-Block, Ground + 01 upper floor (02 Blocks, interconnected) & D-Block, Ground + 01 upper floor Owner/Occupied by Directorate of Education, Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/954 dated 24/11/2021. The said premises was re-inspected by officer concerned of this department on 14/10/2024 in the presence of Ms. Pratibha Sharma (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and the new school block in accordance with rule 33 of Delhi Fire Service Rules, 2010, and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 22/10/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 22/10 /2024 at New Delhi by

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Principal, Bachan Parsad Sarvodaya Kanya Vidyalaya, Deoli, New Delhi -80
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept unlocked & free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

M/117



**INSPECTION REPORT**

1	Name & Address of the Building	Bachan Parsad Sarvodaya Kanya Vidyalaya, Deoli, New Delhi -110080 (ID 1923042)		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	A-Block, Ground + 01 upper floor, B-Block Ground plus 02 upper floor, C-Block, Ground + 01 upper floor (02 Blocks, interconnected) D-Block, Ground + 01 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2021/SZ/954 dated 24/11/2021		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	14-10-2024		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Pratibha Sharma (Principal)		
10	Year of construction	1995 & 2013		
11	Applicant letter No.	J Form dated 27/09/2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	Road width	Required	6 mtr	MR
	Gate width	-NA-	5 mtr	-NA-
	Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	Number of Staircase			
	Upper floors.	06 Nos	B-Block - 3 Nos A Block- 2 Nos C Block- 2 Nos (02 Blocks, interconnected) D-Block- 2 Nos	MR
	Basement floor.	-NA-	-NA-	-NA-
	Width of Staircase			
	Upper floors	1.5 m / 0.75 m	03 in G+2 B-Block (1.70 x 2 & 1.50m) A Block- 1.40 & 1.50 m C Block- 1.50 & 1.50 m (02 Blocks, interconnected) D Block- 1.70 & 1.50m	MR
	Basement floor	-NA-	-NA-	-NA-
	Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	Pressurization	-NA-	-NA-	-NA-
	No. of continuous staircase to terrace	1 No each blocks	Provided	MR
	Width of corridor	-NA-	-NA-	-NA-
	Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	Fire check door.	-NA-	-NA-	-NA-
	Sealing of electrical shafts.	-NA-	-NA-	-NA-
	Fire rating of shaft door.	-NA-	-NA-	-NA-
	Water curtain	-NA-	-NA-	-NA-
	Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	Basement	-NA-	-NA-	-NA-
	Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	Total numbers	Required	30 Nos	MR
	Types	ABC / Co2	ABC / Co2 Type	MR
	ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			

m/18

	Total numbers on each floor.	01 Nos	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7.	Automatic fire detection & alarming system.			
	Type of detectors	-NA-	-NA-	-NA-
	Location of Main Panel	-NA-	-NA-	-NA-
	Location of Repeater Panel	-NA-	-NA-	-NA-
	Alternate source of power	-NA-	-NA-	-NA-
	Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	Basement			
	Upper floors	-NA-	-NA-	-NA-
	Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.	-NA-	-NA-	-NA-
	Size of Riser/Down-comer	-NA-	-NA-	-NA-
	Number of Hydrant per floor	-NA-	-NA-	-NA-
	Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.	-NA-	-NA-	-NA-
	Total number of hydrants.	-NA-	-NA-	-NA-
	Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.	-NA-	-NA-	-NA-
	Ground Level			
	Discharge of main pump.	-NA-	-NA-	-NA-
	Head of main pump.	-NA-	-NA-	-NA-
	Number of main pumps.	-NA-	-NA-	-NA-
	Jockey Pump output.	-NA-	-NA-	-NA-
	Jockey Pump head.	-NA-	-NA-	-NA-
	Standby Pump output.	-NA-	-NA-	-NA-
	Standby Pump head.	-NA-	-NA-	-NA-
	Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	Pump house access.	-NA-	-NA-	-NA-
	Terrace Level			
	Discharge of pump.	450 LPM	Provided	MR
	Head of pump.	40 m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	Underground tank capacity.	-NA-	-NA-	-NA-
	Draw-off connection.	-NA-	-NA-	-NA-
	Fire Service Inlet.	-NA-	-NA-	-NA-
	Access to tank.	-NA-	-NA-	-NA-
	Overhead tank capacity.	10,000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of lift shaft.	-NA-	-NA-	-NA-
	Pressurization of lift lobby.	-NA-	-NA-	-NA-
	Communication in lift car.	-NA-	-NA-	-NA-
	Fireman's switch.	-NA-	-NA-	-NA-
	Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	Total area	-NA-	-NA-	-NA-
	Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	Detector system panel.	-NA-	-NA-	-NA-
	Flow switch panel.	-NA-	-NA-	-NA-

2

n/19

	PA system panel.	-NA-	-NA-	-NA-
	Battery backup.	-NA-	-NA-	-NA-
	Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2021/SZ/954 dated 24/11/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SP)

CFD (MS)   
16/12/2021  
Director   
12/10/21  
ADD

As approved, F.T. letter is put up for  
your signature P1

21/12

Director