

FIRE SAFETY CERTIFICATE

Certified that the M/s Bhai Oil Petrol Pump, Nizamuddin West, New Delhi-13, comprised of **Ground floor only** was granted Fire Safety Certificate by this department vide letter no F6/DFS/MS/SZ/2021/564 dated 17.11.2021. The building/premises was re-inspected by Assistant Divisional Officer (M. Road) from this department on 07.10.2024 in the presence of Mr. Surender Singh (Manager) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises (**Ground floor only**) is fit for occupancy of Group J "Hazardous" (Filling Station) with effect from 15/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 15/10/2024 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Owner/Occupier/Manager, M/s Bhai Oil Petrol Pump, Nizamuddin West, New Delhi-13.

Conditions for the validity of Fire Safety Certificate

1. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipments, electrical gadgets and fitting in the premises shall conform to hazardous area classification for that purpose and be of a type approved by the CCE.
2. In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all people.
3. All fire protection arrangements shall be maintained.
4. Nothing contravention of the explosive Act. 1884 and Rules their under 1983, and static and mobile pressure vessels (unfired) Rules 1981 as modified from time to time.
5. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.
6. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
7. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
11. Any change in the occupancy shall be intimated to this Department and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1	Name & address of the building	M/s Bhai Oil Petrol Pump, Nizamuddin West, New Delhi-13.			
2	Building is comprised of	Ground floor only			
3	Type of occupancy	Group J "Hazardous" (Filling station)			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/SZ/2021/564 dated 17.11.2021			
6	Fire safety direction letter no.	F.5/3A/DFS/2003/683 dated 07.11.2003			
7	Date of inspection	07.10.2024			
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M.Road)			
9	Name of the designation of officer From the building side	Mr. Surender Singh (Manager)			
10	Year of construction	2000-01			
11	Applicant's letter no.	Outdoor diary no. 7206 dated- 30.09.2024			
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements as per Rule 35 (6)	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	6.0 mtrs	Provided	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	NA	NA	NA
		b) Basements	NA	NA	NA
	B	Width of the staircase:			
		a) Upper floors	NA	NA	NA
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	NA	NA	NA
	E	Width of the corridor	NA	NA	NA
	F	Door size	NA	NA	NA
3	Compartmentation:				
	A	Fire Check doors	NA	NA	NA
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft Doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke management System:				
	A	Basements	NA	NA	NA
	B	Upper floors	NA	NA	NA
5	Fire Extinguishers				
	A	Total numbers	Required	25 nos.	MR
	B	Types	DCP, CO ₂ , ABC	CO ₂ , ABC, DCP	MR
	C	ISI marking	ISI marked	Provided	MR

N/24

6	First Aid Hose Reel				
A	Total no. at each floor	NA	NA	NA	
B	Length of hose reel	NA	NA	NA	
C	Nozzle diameter	NA	NA	NA	
7	Automatic Fire Detection and Alarm System (ADAS)				
A	Type of detectors	NA	NA	NA	
B	Location of main Panel	NA	NA	NA	
C	Location of repeater panel	NA	NA	NA	
D	Alternate power source	NA	NA	NA	
E	Hooter's location	NA	NA	NA	
8	MOEFA	NA	NA	NA	
9	Public Address System	NA	NA	NA	
10	Automatic Sprinkler System				
A	Basement	NA	NA	NA	
B	Upper floor	NA	NA	NA	
C	Sprinklers above false ceiling	NA	NA	NA	
11	Internal hydrants				
A	Size of the riser/down comer	NA	NA	NA	
B	No. of hydrants per floor	NA	NA	NA	
C	Hose box	NA	NA	NA	
12	Yard Hydrants				
A	Total no. of hydrants	NA	NA	NA	
B	Hose box	NA	NA	NA	
13	Pumping arrangements				
A	Ground Level	NA	NA	NA	
	a) Discharge & head of main pump	NA	NA	NA	
	b) Number of main pump	NA	NA	NA	
	c) Discharge & head of jockey pump	NA	NA	NA	
	d) Discharge & head of Standby pump	NA	NA	NA	
	e) Auto starting/ manual stopping	NA	NA	NA	
	B	Terrace Level	NA	NA	NA
		a) Discharge of terrace pump	NA	NA	NA
		b) Head of terrace pump	NA	NA	NA
		c) Alternate power supply	NA	NA	NA
d) Auto starting of pump		NA	NA	NA	
14	Captive Water Storage for Fire Fighting				
A	Underground tank capacity	NA	NA	NA	
B	Draw off connection	NA	NA	NA	
C	Fire Service Inlet	NA	NA	NA	
E	Access to tank	NA	NA	NA	
D	Overhead tank capacity	Required	Provided in Hindi & English	MR	
15	'NO Smoking' Signage				
16	Provision of lift				
A	Pressurization of lift shaft	NA	NA	NA	
B	Pressurization of lift lobby	NA	NA	NA	
C	Communication in lift car	NA	NA	NA	
D	Fireman switch	NA	NA	NA	
E	Lift signage	NA	NA	NA	
17	Standby Power Supply				

21

N/25

M/s Bhai Oil Petrol Pump, Nizamuddin West, New Delhi-13.

18	Refuge Area					
	A	location	NA	NA	NA	
	B	Total area	NA	NA	NA	
19	Fire Control Room					
	A	Fire Detection System panel	NA	NA	NA	
	B	Flow switch panel	NA	NA	NA	
	C	P A system panel	NA	NA	NA	
	D	Battery backup	NA	NA	NA	
	E	Building floor plan	NA	NA	NA	
20	Special Fire Protection for special risk if any					
	A	Special Fire Protection system for Protection of Special Risk, if any:	Fire buckets filled with sand. No loose electric wiring seen in premises.		MR	

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/SZ/2021/564 dated 17.11.2021 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

[Signature]
07/10/24

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD) *[Signature]* 14/12/24
 CFO/MS *[Signature]*
 Director *[Signature]* 15/11/24
 ADO/MS