

C19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/2024/ School/NDZ/1028

Dated:..16/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the C.L. Bhalla D.A.V. Sr. Sec. School located at Jhandewalan, (Near Naaz Cinema), Karol Bagh New Delhi in a building comprises of Ground + One Upper floor and school running at ground only owned/occupied by C.L. Bhalla D.A.V. Sr. Sec. School, was earlier granted FSC by this department vide letter No F6/ DFS MS/ 2021/School/ NDZ/1087 dated 28/12/21. Now, the premises was re-inspected by the officer concerned of this department on 09-10-2024 in the presence of Mis Ruchika , Head Clerk and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the premises is fit for occupancy of class Group B "Educational Building" school at ground floor as above with effect from .....16/10/2024 for a period of three years subject to compliance of the conditions mentioned below:

Issued on .....16/10/2024 at New Delhi by.

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi, Old Secretariat, Delhi.
2. The Principal, C.L. Bhalla D.A.V. Sr. Sec. School, Jhandewalan, (Near Naaz Cinema), Karol Bagh New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape such as exits, staircase, etc shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.

W/10  
**INSPECTION REPORT**

1. Name & address of the building:- C.L. Bhalla D.A.V. Sr. Sec. School at Jhandewalan, (Near Naaz Cinema), Karol Bagh New Delhi
2. Type of occupancy:- Educational Group, Gr. + 01 Floor, School running at Ground floor only
3. Type of case:- Renewal
4. Details of previous FSC:- No F6/ DFS MS/ 2021/School/ NDZ/1087 dated 18/12/21.
5. Fire safety directives No.- N/A
6. Date of inspection:- 09/10/24.
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Mis Ruchika , Head Clerk
9. Year of construction:-
10. Applicant's letter No:- Letter no. CLB/24/577 Dated 11/09/24.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	05 mtr.	05 mtr.	MR
	2) Gate width	3.5mtr.	3.5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	01	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	1.06 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	2 mtr.	2.50 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	10Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & w.CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			
	1) Total number of each	N/A	N/A	N/A

N/A

	floor			
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank	N/A	N/A	N/A
15.	Exit Signage.	Required	provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A

N/12

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we renew the FSC issued vide letter no. F6/DFS MS/2021/School/NDZ/1087 dated 28/12/21 under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer



Name :- Ravinder Singh

Designation :- A. D.O. (CC)

D/12  
 11/x/24  
 Dy. C.F.O. (NDZ)  
 C.F.O.  
 14/10/2024  
 Director  
 13/11/24