



**FIRE SAFETY CERTIFICATE**

Certified that the CNG Filling Station (IGL) located at Mayur Vihar, District Centre, Delhi comprised of Ground floor only owned/occupied by Indraprastha Gas Limited was granted FSC by this department vide letter no. F6/DFS/MS/CNG/2021/313 dated 09/07/2021. The premises was re-inspected by the officer concerned of this department on 23/08/2024 in the presence of Mr. Mayank Mishra, (GET- F & S) and found that the said CNG Station have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Storage (CNG Pump) with effect from 11 /10/2024 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 11/10/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. The Dy. General Manager, Fire & Safety, Indraprastha Gas Ltd., IGL Bhawan, Plot No. No. 4, Community Centre, R.K. Puram, Sector - 9, New Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.

M/23

## INSPECTION REPORT

1. Name & address of the building CNG Filling Station (IGL) located at Mayur Vihar, District Centre, Delhi-
2. Type of occupancy:- CNG Storage & Dispensing Unit, Ground floor only.
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/CNG/2021/313 dated 09/07/2021
5. Fire safety directives No.- N/A
6. Date of inspection:- 23/08/24
7. Name of the inspecting officer:- Sh. Yashwant Singh Meena (ADO/LN)
8. Name & designation of officer  
From the building side:- Mr. Mayank Mishra, (GET- F & S)
9. Year of construction:- 1999
10. Applicant's letter No:- Outdoor dairy no.5151 dated 12/08/2024.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	12 mtr.	20 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
<b>3.</b>	<b>Compartmentation</b>	Required	Provided	MR
<b>4.</b>	<b>Smoke Management System</b>	Required	Provided	MR
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	DCP type 10 kg.,	28 nos.	28 nos.	MR
	DCP type 75 kg.,	17 nos.	17 nos.	MR
	CO2 type 4.5 kg	06 nos.	06 nos.	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Gas	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	Required	Provided	MR

u



	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage / No Smoking Signage	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A

(u)

d

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: Co2, DCP local application & Hand held explosive meter			MR

The fire protection systems provided in the building were randomly tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/CNG/2021/313 dated 09/07/2021 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer  
 Name Yashwant Singh Meena  
 Designation ADO (L.N)

Dy. CFO/NDZ

*[Handwritten signature]*  
 03/09/24

C.F.O

*[Handwritten signature]*  
 4/9/2024  
 Director

*[Handwritten signature]*  
 07/10/24

*[Handwritten signature]*  
 7/10/2024

Dy CFO (NDZ)

*[Handwritten signature]*  
 07/10/24

ADO (L.N)