

c/47

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2024/WZ/School/ 1056

Dated: 22/10/2024

FIRE SAFETY CERTIFICATE

Certified that C.R.P.F Public School, Sec-14, Rohini, Delhi-110085, comprised of Basement, Ground + Three upper floors owned/occupied by C.R.P.F Public School was issued FSC by this department vide letter No. F.6/DFSD/MS/2021/WZ/School/591 dated 10.08.2021. The premises was re-inspected by the officer concerned of this department on 07.10.2024 in the presence of Mr. Sanjeev Kapoor, and observed that all the fire prevention & fire safety arrangement as provided in the premises found good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy Educational class with effect from 22/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/10/2024 at New Delhi by

(Atul Garg)
DIRECTOR
Ph: 011-23414000

Copy to :-

1. The Principal, C.R.P.F Public School, Sec-14, Rohini, Delhi-110085.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/ http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	C.R.P.F Public School, Sec-14, Rohini, Delhi-110085.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Basement + Gr. + 03 upper floors)			
4. Details of Previous NOC	F.6/DFSD/MS/2021/WZ/School/591 dated 10.08.2021.			
5. Fire Safety directives letter No	NBV Part-IV			
6. Date of inspection	07.10.2024			
7. Name of Inspecting Officer	A.K.Sharma ADO(Rohini)			
8. Name and designation of officers From the building side	Mr. Sanjeev Kapoor			
9. Year of Construction	1992			
10. Applicant's letter No.	Online e-mail dated 17.09.2024			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02nos.	02nos.	MR
	• Basements	02nos.	02nos.	MR
	b. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	-		
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	-12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	01 @ 300 each	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			

	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	03	Provided	MR
	• Hose Box	03	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 & 180lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	1,00,000ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	110KVA	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA

NA
NA
NA

Location		NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• FA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 629 dated 12.09.2024, the FSC issued vide letter no. F F.6/DFSD/MS/2021/WZ/School/591 dated 10.08.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended



Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

DO (N/W)

[Signature]
07/10/2024

[Signature]
by CFO (w2)

[Signature]
16/10/2024

[Signature]
16/10/2024

[Signature]
19/10/24

[Signature]
ADP Rm

Fi letter is put up for kind perusal and signature please.

[Signature]
Director

[Signature]
18/10/24

01...605...M...
Dated...16/10/2024