



2114

7
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2024/ 1050

Dated: 22/10/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Bal Vidyalaya, located at Moti Nagar, New Delhi-110015. (School ID -1516010), in a building comprised of ground plus three upper floors, Owned/occupied by Govt. Sarvodaya Bal Vidyalaya, was issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/143 dated 10/02/2022. The premise was re-inspected by the officer concerned by this department on 27/09/2024 in the presence of Sh. Guru Dutt (Principal) and observed that the fire prevention and fire safety arrangements/equipments provided in the building found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules 2010 and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 22/10/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below. Issued on 22/10/2024..... at New Delhi.

Atul Garg
Director

Copy to: -

1. The Principal M/s Govt. Sarvodaya Bal Vidyalaya, located at Moti Nagar, New Delhi-110015. (School ID -1516010), Email ID- sbvmn 1516010" sbv1516010@gmail.com
2. Director of Education, Old.Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

18/10/2024

INSPECTION REPORT

1. Name & address of the building	Govt. Sarvodaya Bal Vidyalaya Located at, Moti Nagar, New Delhi-110015. (School ID -1516010)
2. Type of Occupancy	Educational (Ground Floor + 03 Upper Floor)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/WZ/2022/143 dated 10/02/2022
5. Fire Safety directives letter No	DOE Circular 3298-3398 dated 01/03/2011/NBC Part-IV
6. Date of inspection	27/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Guru Dutt (Principal)
9. Year of Construction	2021 As per previous Insp. report dtd.- 03/12/2021
10. Applicant's letter No.	Email dated 29/08/2024

The Said school building comprised of ground and three upper floors, was issued FSC by this department vide letter No. F6/DFS/MS/School/WZ/2022/143 dated 10/02/2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	Provided	MR
	g. Door Size	2 x 1.20 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

16			
6	First-Aid Hose Reels.		
	• Total numbers on each floor	2	Provided
	• Length of hose reel hose	30 m	Provided
	• Nozzle diameter	5 mm	Provided
7	Automatic fire detection and alarming system.		
	• Type of detectors	NA	NA
	• Location of Main Panel	NA	NA
	• Location of Repeater Panel	NA	NA
	• Alternate source of power	NA	NA
	• Hooters' Location	NA	NA
8	MOEFA	NA	NA
9	Public Address System.	NA	NA
10	Automatic Sprinkler System.		
	• Basement	NA	NA
	• Upper Floor	NA	NA
	• Sprinkler above false ceiling	NA	NA
11	Internal Hydrants		
	• Size of riser/down-comer	NA	Provided
	• Number of hydrants per floor	NA	Provided
	• Hose Box	NA	Provided
12	Yard Hydrants.		
	• Total number of hydrants	NA	NA
	• Hose Box	NA	NA
13	Pumping Arrangements.		
	• Ground Level		
	➤ Discharge of main Pump	NA	NA
	➤ Head of Main pump	NA	NA
	➤ Number of main pumps	NA	NA
	➤ Jockey Pump out put	NA	NA
	➤ Jockey pump head	NA	NA
	➤ Standby Pump out put	NA	NA
	➤ Standby Pump Head	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA
	➤ Pump House Access	NA	NA
	• Terrace level		
	➤ Discharge of pump	450 LPM	Provided
	➤ Head of the pump	40 m	Provided
	➤ Power Supply	Required	Provided
	➤ Auto Starting of pump	Required	Provided
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NR	NR
	➤ Draw-off connection	NR	NR
	➤ Fire service inlet	NR	NR
	➤ Access to tank	NR	NR
	• Overhead Tank capacity	10,000 ltrs	Provided
15	Exit Signage.	Required	Provided

113

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

7/ADO/MN
67/16/2024

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC/FSC issued vide letter no. F6/DFS/MS/School/WZ/2022/143 dated 10/02/2022 renewal under 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Accepted (wiz)~~

Signature
07/10/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

70/406/2024
Date: 16/10/2024

16/10

CFD
16/10/2024
Director
Signature

ADO/MN

Sir, F. T is put up for your kind personal & signature pls.

Signature
18/10/2024