

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No. F.6/DFS/MS/School/2024/SZ/1002

Dated: 09/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Guru Harkrishan Public School** at D-101, Fateh Nagar, New Delhi-110018, comprised of three blocks namely Senior block comprised of basement, ground floor plus three upper floors, Primary block comprised of basement, ground floor plus two upper floors & Middle Block ground floor only, owned/occupied by Guru Harkrishan Public School was issued FSC vide letter no. F.6/DFS/MS/School/2021/SZ/643 dated 24.08.2021. The School building was re-inspected by the officer concerned of this department on dated 30.09.2024 in the presence of Rash Pal Singh (Caretaker) and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (except basement of Senior & Primary Block) is fit for occupancy class "Educational" w.e.f. 09/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 09/10/2024 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Principal, Guru Harkrishan Public School at D-101, Fateh Nagar, New Delhi-110018.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.
3. Executive Engineer, Bldg., MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027. **w.r.t the use of basement.**

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Basement in Senior & Primary Block shall not be used for school activity.

## INSPECTION REPORT

1. Name & address of the building : Guru Harkrishan Public School, Fateh Nagar, New Delhi-110018.
2. Building comprised of : Three blocks namely Senior Block(Basement,G+3), primary block (Basement,G+2) & Middle Block ground floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/643 dated 24.08.2021
6. Fire Safety directives letter No : N/A
7. Date of inspection : 30.09.2024
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers  
From the building side : Rash Pal Singh (Caretaker)
10. Year of Construction : 2013
11. Applicant's letter No. : GHPS/FN/9983 dated 16.07.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible 4.5 m NA	7.5 mtrs Directly accessible from road NA	M/R M/R NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02 No's in Sr. Blk & 01 No. in Pry Blk.	02 No's in Sr. Blk (one of them is Ramp) & 01 No. in Pry Blk	MR
	• Basement	02 No's in Sr. Blk basement is not in use in Pry & Mdl Blk	02 No's in Sr. Blk & basement is not in use in Pry Blk	MR
	b. Width of staircases			
	• Upper Floor	1.50 m	1.90 m s/case & 1.50 m ramp in Sr. Blk & 1.50 m in Pry. Blk	MR
	• Basements	1.50 m in sr. blk basement is not in use in Pry & Mdl Blk	1.90 & 1.50 m in Sr. Blk basement is not in use in Pry & Mdl Blk	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	M/R
	e. Width of Corridor	1.50 m	2.75 m	M/R
	f. Door Size	1.0 m	1.20 m	M/R (Students are less than 45 in each class room)
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	Required in Sr. Blk. & basement is not in use in Pry Blk	Exhaust fans are provided in Sr. Blk & . basement is not in use in Pry Blk	M/R
	• Upper floors	Required	Natural ventilation	M/R
5.	<b>Fire Extinguishers</b>			
	• Total numbers	24 No.'s	Provided	M/R
	• Types	ABC/CO2 type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R



N/23

17.	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	64 KVA	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2021/SZ/643 dated 24.08.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

**Note:** - School having 03 blocks namely Senior block, Primary block & middle block. Senior block comprised of basement (Storage), ground plus three upper floors and Primary block comprised of basement (storage), ground plus two upper floors & middle block comprised of ground floor (Gurdwara, canteen & one office) only. As per undertaking given by Principal (placed at C-27) that the basement of senior block and primary block only used for storage purpose and not used for school activity (Photo enclosed with undertaking).

*R.K. Yadav*  
3/10/2024

Signature of Inspecting Officer  
Name: - R.K. Yadav  
Designation: - ADO (JKP)

DO (South West)

*4/10/24*  
*4/10/2024*  
*Director*  
*4/10/24*

*4/10/24*