



F6/DFS/MS/Metro/SZ/2024/ 642

Dated: 18/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Hazrat Nizamuddin Underground Metro Station (Line-7)**, located at Hazrat Nizamuddin, New Delhi, comprising of **Four Levels (undercroft, Platform, Concourse & Ground Level)** was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/SZ/2021/Metro/644 dated 30.12.2021. The building/premises was re-inspected by officer concerned from this department on 15.10.2024 in presence of Mr. Sanyam Jain (AM/Fire) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of **"Assembly (D-7)"** with effect from 18/10/2024..... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 18/10/2024.....at New Delhi by


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The JGM/E & M, DMRC Ltd., Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-01.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. Basement shall be used as per NBC/BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The access around the blocks as submitted in the plans submitted by principal Architect Design plus shall be kept clear of any obstruction for free movement of fire units in case of emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

N/19

INSPECTION REPORT

1	Name & address of the building	Hazrat Nizamuddin Underground Metro Station Line-7		
2	Building is comprised of	Undercroft, Platform, Concourse, Ground Floor		
3	Type of occupancy	Assembly (D - 7)		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/SZ/2021/Metro/644 dated 30.12.2021		
6	Fire safety direction letter no.	F.6/DFS/MS/2013/1831 dated 19/07/2013		
7	Date of inspection	15.10.2024		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mr. Sanyam Jain (AM/Fire)		
10	Year of construction	2018		
11	Applicant's letter no.	Outdoor diary no. 5250 dated 13.08.2024		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ NFPA	Provided at Site	Remarks MR/NMR
1	Access To Building:			
	Road width	Required	10.0 mtrs	MR
	Gate width	NA	6.0 mtrs	NA
	Width of internal road	Approachable	On road	MR
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	NA	NA
	b	Basement	1. Undercroft to platform – 2 nos. 2. Platform to Concourse- 6 nos. + 03 Escalator 3. Concourse to GF – 05 nos. + 04 Escalator	MR (50% capacity of escalator is counted for evacuative in NFPA)
	B	Width of staircases		
	a	Upper floor	NA	NA
	b	Basement	1.12 m & 0.91 m (maintenance staircase)	MR (Based on evacuation calculation submitted by DMRC as per NFPA)
	C	Protection of exits		
	a	Fire check door	Required	MR
	b	Pressurization	Required in fireman & emergency stairs	MR
	D	No. of continuous staircases to terrace	NA	NA
	E	Width of corridor	0.91 mtrs	MR
	F	Door size	0.91 mtrs	MR
3	Compartmentation:			
	A	Fire check door	Required	MR
	B	Sealing of electrical shafts	Required	MR
	C	Fire rating of shaft door	30 minutes & 3 hours	MR
	D	Water curtain	NA	NA
	E	Fire dampers	Required	MR
4	Smoke Management System:			
	A	Basement	Required	MR
	B	Upper floor	NA	NA

DA


5. Fire Extinguisher:				
A	Total numbers	104	Provided	MR
B	Types	Required	CO ₂ & W.CO ₂ & ABC	MR
C	ISI marking	ISI marked	ISI marked	MR
6 First-Aid-Hose Reels:				
A	Total numbers of each floor	2 No.in Ancillary building - 12 nos. At Concourse 09 nos. at Platform	Provided	MR
B	Length of hose reel hose	36m	36 m	MR
C	Nozzle diameter	6mm	6 mm	MR
7 Automatic Fire Detection And Alarming System:				
A	Type of detectors	Required	Smoke type	MR
B	Location of main panel	Required	Station Control Room	MR
C	Location of repeater panel	Required	Fireman Staircase	MR
D	Alternate source of power	Required	Provided	MR
E	Hooters	Required	Provided at all levels	MR
8	MOEFA:	Required	Provided	MR
9	Public Address System:	Required	Provided	MR
10 Automatic Sprinkler System:				
A	Basement	Required in following rooms;- mess store, security, locker	Provided	MR
B	Upper floor	NA	NA	NA
C	Sprinkler, above false ceiling	NA	NA	NA
11 Internal Hydrants:				
A	size of riser/down-comer	150 mm	Provided	MR
B	Number of hydrants per floor	Ancillary building - 2 nos. Concourse 12 nos. 09 nos. at each platform	Provided	MR
C	Hose box	Ancillary building - 2 nos. Concourse 12 nos. 09 nos. at each platform	Provided	MR
12 Yard Hydrants:				
A	Total number of hydrants	01 no.	Provided	MR
B	Hose box	01 no in ancillary building 01no. at each tunnel Portal	Provided	MR
13 Pumping Arrangements:				
A	Ground level			
a)	Discharge of main pump	2839 LPM	Provided	MR
b)	Head of main pump	88 m for hydrant & 75 m for sprinkler	Provided	MR
c)	Number of main pumps	2 nos.	Provided	MR
d)	Jockey pump out put	2 x 189 LPM	Provided	MR
e)	Jockey pump head	88 m for hydrant & 75 m for sprinkler	Provided	MR
f)	Standby pump out put	2 x 2839 LPM (eclectic)	Provided	MR
g)	Standby pump head	88 m for hydrant & 75 m for sprinkler	Provided	MR
h)	Auto starting /manual stopping	Required	Provided	MR
i)	Pump house access	Required	Provided	MR
B	Terrace level		Provided	MR
a)	Discharge of pump	NA	NA	NA
b)	Head of the pump	NA	NA	NA
c)	Power supply	NA	NA	NA
d)	Auto starting of pump	NA	NA	NA

14	Captive Water Storage For Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	Required	Provided	MR
	C	Fire service inlet	Required	Provided	MR
	D	Access to tank	Required	Provided	MR
	E	Overhead tank capacity	2,00,000 ltrs	Provided	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	Required	Provided	MR
	D	Firemen's grounding switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	Standby Power Supply:		Required	Provided DG Set	MR
18	Refuge Area:				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA
19	Fire Control Room :				
	A	Detector system panel	Required in SCR	Provided	MR
	B	Flow switch panel	Required	Provided	MR
	C	PA system panel	Required	Provided	MR
	D	Battery backup	Required	Provided	MR
	E	Building floor plans	Required	Provided	MR
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		Clean agent flooding system for electrical panels & transformer	Total Gas flooding & NOVAC for Transformer & electrical panels	MR

LEGENDS:-Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no F6/DFS/MS/SZ/2021/Metro/644 dated 30.12.2021 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (M. Road)

DO (SD)  15/12/21

CO (R/S) 

16/12/2021
 Director (M) 
