



No. F6/DFS/MS/School/NDZ/2024/ 1023

Dated: / 6/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Rajkiya Pratibha Vikas Vidyalaya** located at **Gandhi Nagar, Delhi - 110031**, comprised of **ground plus three upper floors (New Building)** owned/occupied by **Rajkiya Pratibha Vikas Vidyalaya** have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 07/10/2024 in the presence of Mrs. Alka Panwar (Principal) & Mr. Anil Kumar (Estate Manager) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. and that the school building is fit for occupancy class B **“Educational Building”** ground plus three upper floors only with effect from 16/10/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 16/10/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR

o/c  DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi - 110054.
2. The Principal, Rajkiya Pratibha Vikas Vidyalaya located at Gandhi Nagar, Delhi - 110031.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/26

INSPECTION REPORT

1	Name & address of the building	Rajkiya Pratibha Vikas Vidyalaya located at Gandhi Nagar, Delhi - 110031.		
2	Building is comprised of	Ground plus three upper floors. (New Building)		
3	Type of occupancy	Educational Building		
4	Type of case	New Case		
5	Details of previous FSC	New		
6	Fire safety directives letter no.	NBC Part-IV		
7	Date of inspection	07/09/2024		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/Laxmi Nagar		
9	Name of the designation of officer from the building side	Mrs. Alka Panwar (Principal)		
10	Year of construction	2022		
11	Applicant's letter no.	Email dated 19/09/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	06 meters.	09 meters	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	06 nos.	06 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 meters. each	1.80 meters. each	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	05 no.	05 no.	MR
E	Width of corridor	1.50 meters.	2.10 meters	MR
F	Door size & No. of Doors	1.20 meters x 02 nos.	1.20 meters x 02 nos.	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

W

5. Fire Extinguisher:					
	A	Total numbers	24 nos.	28 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:					
	A	Total numbers of each floor	07 nos.	07 nos.	MR
	B	Length of hose reel hose	30 meters.	30 meters.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8 MOEFA:					
			N/A	N/A	N/A
9 Public Address System:					
			N/A	N/A	N/A
10 Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:					
	A	Size of riser/down-comer	N/A	100 mm	N/A
	B	Number of hydrants per floor	N/A	07 nos.	N/A
	C	Hose box	N/A	07 nos.	N/A
12 Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:					
1 Ground level					
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2 Terrace Level					
	A	Discharge of pump	450 LPM	450 LPM X 02	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

W

✓

N/28

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 liters.	25,000 liters. MR
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

No file is pending with me before disposal of this case.



Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO/Laxmi Nagar

~~CFO/NDZ~~ KVP
10/10/24

C.F.O |
11/10/2024

Director |
11/10/24

Sir. F.T Letter is setup for sign. Please

Director |
15/10/24


14/10/2024