



FIRE SAFETY CERTIFICATE

Certified that the **Sanjay Memorial Public School** located at **East Vinod Nagar, Delhi - 110092**, comprised of Basement (Store), ground plus three upper floors, (School is running ground plus two upper floor only), third floor used of residence for guard, owned / occupied by **Sanjay Memorial Public School**, was issued FSC vide letter No. F6/MS/DFS/06/2811 dated 26/09/2006. The School building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and re-inspected by the officer concerned of this department on 04/10/2024 in presence of Mrs. Sonia Chauhan (Principal) of the school and that the school building is fit for occupancy class (Group-B) "**Educational Building**" for ground plus two upper floor only with effect from 16/10/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 16/10/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

D/C DELHI FIRE SERVICE

Copy to:-

1. The Principal, Sanjay Memorial Public School located at East Vinod Nagar, Delhi - 110092.
2. The Director of Education, GNCT of Delhi, Old Secretartion, Delhi - 110091.

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground plus two upper floors only.
2. Presently basement is being used for storage purpose only.
3. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
4. All the means of escape shall be kept free of all the type of obstruction all the time.
5. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
6. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
7. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/07

INSPECTION REPORT

| | | | | |
|------|---|---|------------------|-------------------|
| 1 | Name & address of the building | Sanjay Memorial Public School located at East Vinod Nagar, Delhi - 110092. | | |
| 2 | Building is comprised of | Basement (Store) + Ground + Three Upper Floors (School is running on G + 2 upper floor only), Third floor guard residence purpose used. | | |
| 3 | Type of occupancy | Educational Building | | |
| 4 | Type of case | Renewal Case | | |
| 5 | Details of previous FSC | F6/MS/DFS/06/2811 dated 26/09/2006 | | |
| 6 | Fire safety directives letter no. | Circular Director of Education dated 17/01/2005 | | |
| 7 | Date of inspection | 04/10/2024 | | |
| 8 | Name of the inspecting officers | Yashwant Singh Meena ADO, Laxmi Nagar | | |
| 9 | Name of the designation of officer from the building side | Mrs. Sonia Chauhan (Principal) | | |
| 10 | Year of construction | 2005 | | |
| 11 | Applicant's letter no. | Outdoor diary no. 7200 dated 30/09/2024 | | |
| S.No | Minimum standard of fire prevention and fire safety U/R 33 | Circular Requirement | Provided at site | Remarks MR/NMR |
| 1 | Access to Building: | | | |
| | A Road width | 6.0 mtrs. | 6.0 mtrs. | MR |
| | B Gate width | N/A | N/A | N/A |
| | C Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits: | | | |
| | A Number of staircases | | | |
| | a Upper floor | 01 no. | 01 no. | MR (old accepted) |
| | b Basement | N/A | N/A | N/A |
| | B Width of staircases | | | |
| | a Upper floor | 1.5 meters. | 0.96 meter. | MR (old accepted) |
| | b Basement | N/A | N/A | N/A |
| | C Protection of exits | | | |
| | a Fire check door | N/A | N/A | N/A |
| | b Pressurization | N/A | N/A | N/A |
| | D No. of continuous staircases to terrace | 01 no. | 01 no. | MR |
| | E Width of corridor | 1.25 mtrs. | 1.25 mtrs. | MR (old accepted) |
| | F Door size | 1.0 mtr. | 1.0 mtr. | MR |
| 3 | Compartmentation: | | | |
| | A Fire check door | N/A | N/A | N/A |
| | B Sealing of electrical shafts | N/A | N/A | N/A |
| | C Fire rating of shaft door | N/A | N/A | N/A |
| | D Water curtain | N/A | N/A | N/A |
| | E Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management System: | | | |
| | A Basement | N/A | N/A | N/A |
| | B Upper floor | N/A | N/A | N/A |

W

N/08

Sanjay Memorial Public School located at East Vinod Nagar, Delhi.

| | | | | |
|--|--------------------------------|-----------------------|-----------------------|-----|
| 5. Fire Extinguisher: | | | | |
| A | Total numbers | 06 nos. | 10 nos. | MR |
| B | Types | CO ₂ & ABC | CO ₂ & ABC | MR |
| C | ISI marking | ISI Marked | Provided | MR |
| 6 First-Aid-Hose Reel: | | | | |
| A | Total numbers of each floor | 01 no. | 01 no. | MR |
| B | Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| C | Nozzle diameter | 05 mm | 05 mm | MR |
| 7 Automatic Fire Detection and Alarming System: | | | | |
| A | Type of detectors | N/A | N/A | N/A |
| B | Location of main panel | N/A | N/A | N/A |
| C | Location of repeater panel | N/A | N/A | N/A |
| D | Alternate source of power | N/A | N/A | N/A |
| E | Hooters | N/A | N/A | N/A |
| 8 | MOEFA: | N/A | N/A | N/A |
| 9 | Public Address System: | N/A | N/A | N/A |
| 10 Automatic Sprinkler System: | | | | |
| A | Basement | N/A | N/A | N/A |
| B | Upper floor | N/A | N/A | N/A |
| C | Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 Internal Hydrants: | | | | |
| A | Size of riser/down-comer | N/A | N/A | N/A |
| B | Number of hydrants per floor | N/A | N/A | N/A |
| C | Hose box | N/A | N/A | N/A |
| 12 Yard Hydrants: | | | | |
| A | Total number of hydrants | N/A | N/A | N/A |
| B | Hose box | N/A | N/A | N/A |
| 13 Pumping Arrangements: | | | | |
| 1 Ground level | | | | |
| A | Discharge of main pump | N/A | N/A | N/A |
| B | Head of main pump | N/A | N/A | N/A |
| C | Number of main pumps | N/A | N/A | N/A |
| D | Jockey pump out put | N/A | N/A | N/A |
| E | Jockey pump head | N/A | N/A | N/A |
| F | Standby pump out put | N/A | N/A | N/A |
| G | Standby pump head | N/A | N/A | N/A |
| H | Auto starting /manual stopping | N/A | N/A | N/A |
| I | Pump house access | N/A | N/A | N/A |
| 2 Terrace Level | | | | |
| A | Discharge of pump | 220 LPM | 220 LPM | MR |
| B | Head of the pump | 40 m | 40 m | MR |
| C | Power supply | Required | Provided | MR |
| D | Auto starting of pump | Required | Provided | MR |

W

✓

N109

Sanjay Memorial Public School located at East Vinod Nagar, Delhi-

| | | | | |
|-----------|---|---------------|---------------|-----|
| 14 | Captive Water Storage for Fire Fighting: | | | |
| A | Underground tank capacity | N/A | N/A | N/A |
| B | Draw-off connection | N/A | N/A | N/A |
| C | Fire service inlet | N/A | N/A | N/A |
| D | Access to tank | N/A | N/A | N/A |
| E | Overhead tank capacity | 2,500 liters. | 2,500 liters. | MR |
| 15 | Exit Signage: | Required | Provided | MR |
| 16 | Provision of Lifts: | | | |
| A | Pressurization of lift shaft | N/A | N/A | N/A |
| B | Pressurization of lift lobby | N/A | N/A | N/A |
| C | Communication in lift car | N/A | N/A | N/A |
| D | Firemen's grounding switch | N/A | N/A | N/A |
| E | Lift signage | N/A | N/A | N/A |
| 17 | Standby Power Supply: | N/A | N/A | N/A |
| 18 | Refuge Area: | | | |
| A | Total area | N/A | N/A | N/A |
| B | Location | N/A | N/A | N/A |
| 19 | Fire Control Room: | | | |
| A | Detector system panel | N/A | N/A | N/A |
| B | Flow switch panel | N/A | N/A | N/A |
| C | PA system panel | N/A | N/A | N/A |
| D | Battery backup | N/A | N/A | N/A |
| E | Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection system was randomly checked and tested and was found functional at the time of inspection basement (Store) and third floor is being used residence for guard. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/539 dated 20/08/2024 by this department has been rectified by the management.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/MS/DFS/06/2811 dated 26/09/2006, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.



Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (Laxmi Nagar)

~~DY. CEO/NDZ~~

C.F.O.

King
10/10/24

Mugh
10/10/2024

Director

P.T.O