

**FIRE SAFETY CERTIFICATE**

Certified that the St. Andrews Scot School located at 11/56, West Azad Nagar, Lane No. 7, Delhi - 110051, comprised of ground plus one upper floor owned/occupied by St. Andrews Scot School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/NDZ/2209 dated 25/11/2019. The School building was re-inspected by the officer concerned of this department on 28/09/2024 in presence of Mr. Jagdish Sondhi (Manager) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class Group B "Educational Building" with effect from 09/10/2024 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 09/10/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to: -**

1. The Joint Director of Education (Land & Estate), Directorate of Education, Lucknow Road, Delhi - 110054.
2. The Manager, St. Andrews Scot School located at 11/56, West Azad Nagar, Lane No. 7, Delhi - 110051.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

(11)8  
**INSPECTION REPORT**

1	Name & address of the building	St. Andrews Scot School located at 11/56, West Azad Nagar, Lane No. 7, Delhi - 110051.		
2	Building is comprised of	Ground plus one upper floor.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2019/NDZ/2209 dated 25/11/2019		
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	28/09/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Jagdish Sondhi (Manager)		
10	Year of construction	2005		
11	Applicant's letter no.	Outdoor dairy no. 6886 dated 23/09/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old Circular Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	6.0 mtrs.	4.5 mtrs. ✓	MR (Old Case)
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	02 no.	02 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 mtrs.	1.0 mtr. & 0.95 mtr. ✓	MR (Old Case)
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	02 no. ✓	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
F	Door size	1.0 mtr.	1.16 mtr. ✓	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

5/1/19

<b>5.</b>	<b>Fire Extinguisher:</b>			
	<b>A</b>	Total numbers	08 nos.	08 nos. / MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC MR
	<b>C</b>	ISI marking	ISI Marked	Provided MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>			
	<b>A</b>	Total numbers of each floor	01 no.	01 no. / MR
	<b>B</b>	Length of hose reel hose	30 mtrs	30 mtrs MR
	<b>C</b>	Nozzle diameter	50 mm	05 mm MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>			
	<b>A</b>	Type of detectors	N/A	N/A N/A
	<b>B</b>	Location of main panel	N/A	N/A N/A
	<b>C</b>	Location of repeater panel	N/A	N/A N/A
	<b>D</b>	Alternate source of power	N/A	N/A N/A
	<b>E</b>	Hooters	N/A	N/A N/A
<b>8</b>	<b>MOEFA:</b>		Required	Required MR
<b>9</b>	<b>Public Address System:</b>		N/A	N/A N/A
<b>10</b>	<b>Automatic Sprinkler System:</b>			
	<b>A</b>	Basement	N/A	N/A N/A
	<b>B</b>	Upper floor	N/A	N/A N/A
	<b>C</b>	Sprinkler above false ceiling	N/A	N/A N/A
<b>11</b>	<b>Internal Hydrants:</b>			
	<b>A</b>	Size of riser/down-comer	N/A	N/A N/A
	<b>B</b>	Number of hydrants per floor	N/A	N/A N/A
	<b>C</b>	Hose box	N/A	N/A N/A
<b>12</b>	<b>Yard Hydrants:</b>			
	<b>A</b>	Total number of hydrants	N/A	N/A N/A
	<b>B</b>	Hose box	N/A	N/A N/A
<b>13</b>	<b>Pumping Arrangements:</b>			
<b>1</b>	<b>Ground level</b>			
	<b>A</b>	Discharge of main pump	N/A	N/A N/A
	<b>B</b>	Head of main pump	N/A	N/A N/A
	<b>C</b>	Number of main pumps	N/A	N/A N/A
	<b>D</b>	Jockey pump out put	N/A	N/A N/A
	<b>E</b>	Jockey pump head	N/A	N/A N/A
	<b>F</b>	Standby pump out put	N/A	N/A N/A
	<b>G</b>	Standby pump head	N/A	N/A N/A
	<b>H</b>	Auto starting /manual stopping	N/A	N/A N/A
	<b>I</b>	Pump house access	N/A	N/A N/A
<b>2</b>	<b>Terrace Level</b>			
	<b>A</b>	Discharge of pump	220 LPM	220 LPM / MR
	<b>B</b>	Head of the pump	40 mtrs.	40 mtrs. / MR
	<b>C</b>	Power supply	Required	Required MR
	<b>D</b>	Auto starting of pump	Required	Required MR

N/D

14	<b>Captive Water Storage for Fire Fighting:</b>				
	A	Underground tank capacity	N/A	N/A	N/A
	B	Draw-off connection	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A
	E	Overhead tank capacity	25,00 liter	25,00 liter	MR
15	<b>Exit Signage:</b>		N/A	N/A	N/A
16	<b>Provision of Lifts:</b>				
	A	Pressurization of lift shaft	N/A	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A	N/A
	C	Communication in lift car	N/A	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A	N/A
	E	Lift signage	N/A	N/A	N/A
17	<b>Standby Power Supply:</b>		N/A	N/A	N/A
18	<b>Refuge Area:</b>				
	A	Total area	N/A	N/A	N/A
	B	Location	N/A	N/A	N/A
19	<b>Fire Control Room:</b>				
	A	Detector system panel	N/A	N/A	N/A
	B	Flow switch panel	N/A	N/A	N/A
	C	PA system panel	N/A	N/A	N/A
	D	Battery backup	N/A	N/A	N/A
	E	Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>		N/A	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2019/NDZ/2209 dated 25/11/2019, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.

30/9/2024

Signature of the Inspecting Officer

Name: Yashwant Singh Meena

Designation: ADO (Laxmi Nagar)

~~DY.CFO/NDZ~~

C.F.O.

4/10/2024

Director

~~ADP  
01/10/24~~

~~ADP  
01/10/24~~

~~ADP/LW~~