



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 342

Dated: 18 / 10 / 2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s **BLAQ** (A unit of Boisson Kitchen & Bar Pvt. Ltd) at D-21, Third Floor, Defence Colony, New Delhi-110024, comprised of Basement, Stilt, Ground & 03 Upper Floors, but the restaurant running at 3<sup>rd</sup> Floor only, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2020/SZ/01 dated 01/01/2020. The restaurant was re-inspected by the officer concerned of this department on 11/10/2024 in the presence of Mr. Ankit Verma (Partner) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premise is fit for occupancy class "Assembly Group D" (Eating House) up to 31/03/2027 in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/10/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police, Licensing Branch, First Floor, Police Station Defence Colony, New Delhi-110049 (w.r.t. MHA ID No. 2024100415235 dated 04/10/2024)
2. Mr. Tarun Agarwal M/s BLAQ (A unit of Boisson Kitchen & Bar Pvt. Ltd), D-21, Third Floor, Defence Colony, New Delhi-110024

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



N-12

**INSPECTION REPORT**

1.	Name & address of the building	M/s <b>BLAQ</b> (A Unit of Boisson Kitchen & Bar Pvt. Ltd), D-21, Third Floor, Defence Colony, New Delhi-110024		
2.	Type of Occupancy	Assembly Group 'D' (Eating House)		
3.	Building Comprised of	Basement, Stilt, Ground + 03 upper floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/EH/2020/SZ/01 dated 01/01/2020		
6.	Fire Safety directives/approval letter	Nil		
7.	Date of inspection	11/10/2024		
8.	Name of Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from building side	Mr. Ankit Verma (Partner)		
10.	Year of Construction	2017	<b>Restt. at 3<sup>rd</sup> Floor only</b>	
11.	Applicant letter No. / Online MHA	ID No. <b>20240100415235</b> dated 04/10/2024		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	Provided	MR
	• Gate width	4.5 mtr	Abuts on road	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	NA	NA
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper floors	2m & 1.5m	NA	NA
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	02 Nos	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	2 x 1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Managements System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos	06 Nos	MR
	• Types	ABC / CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Hose-Reel	One	MR
	• Length of hose reel hose		30m	MR
	• Nozzle diameter		5mm	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> </ul>	Required	Heat & Smoke	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	3 <sup>rd</sup> Floor	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> </ul>	100mm	100mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	One	One	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	One	One	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	-NA-	-NA-	-NA-
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump</li> </ul>	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	70m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	One	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	180 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	70m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	40m	40m	MR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw of connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	5,000 Ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pressurization of lift lobby</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Communication in lift Car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Lift Signage</li> </ul>	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	-NA-	-NA-	-NA-

SR



N-14

19.	Fire Control Room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any	-NA-	-NA-	-NA-

The fire protection system provided in the building/premises were checked, tested at random and found functional at the time of inspection. The shortcomings issued vide this department letter No. F.6/DFS/MS/EH/SZ/2023/127 dated 14/03/2023 found complied.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, renewal of fire safety certificate issued vide letter No. F.6/DFS/MS/EH/2020/SZ/01 dated 01/01/2020, under rule 37 of DFS Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Santosh Kumar*  
16.10.24

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD) *[Signature]*

*cto/MS*  
*[Signature]*  
18/10/24

*Director*  
*[Signature]*  
18/10/24

As approved, fair typed letter is put up for kind perusal/sign for.

*Director*  
*[Signature]*  
18/10/24

*[Signature]*  
18/10/24

*[Signature]*  
18/10/24