



No. F6/DFS/MS/EH/2024/ 331

Dated: 14/10/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Vaishno Punjabi Dhaba located at Ground floor, A-13, Sarai Pipal Thala, Adarsh Nagar, Delhi-110033 in the building comprised of ground & 03 upper floors owned/occupied by M/s Vaishno Punjabi Dhaba was issued fire safety certificate vide letter no. F6/DFS/MS/2021/338 Dated 22.11.2021. The premises was inspected by the officer concerned of Fire Service on 07.10.2024 in the presence of Sh. Sagar and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "Group-D Assembly (Restaurant) for ground floor only" with effect from --14/10/2024 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...14/10/2024... at New Delhi by

(Atul Garg)
Director

Ph-011-23414000
etc

Copy to:-

1. M/s Vaishno Punjabi Dhaba located at Ground floor, A-13, Sarai Pipal Thala, Adarsh Nagar, Delhi- 110033.

Conditions for the validity of Fire Safety Certificate:

1. **This Fire Safety Certificate is valid only for restaurant at ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.**
2. All the means of escape shall be kept free from any type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Vaishno Punjabi Dhaba, A-13, Ground floor, Sarai Pipal Thala, Extn. Adarsh Nagar, Delhi- 110007,
2. Type of Occupancy : Assembly (Restaurant)
3. Composition of building : Ground & 03 upper floors **but restaurant running at ground floor only**,
First floor- Guard room, 2nd & 3rd floor vacant
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2021/338 dated 22.11.2021
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 07.10.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Sagar
10. Year of Construction/conversion : 1998 as per MHA detail
11. Applicant's letter No. : Online Portal I. D. no. 2024093015019 dated 01.10.2024

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC-2016 requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits (Restaurant at GF only)			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	1.50m	1.50m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors (Ground Floor)	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	05nos	06nos	MR
	• Types	ABC/Co2	ABC-5/Co2-1	MR

		Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor (Ground floor)	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			
	NA	NA	NA	

Note:-

- (a) The total covered area of the ground floor Restaurant is 93.64sqm (Approx) including seating area, kitchen area, toilet area,
- (b) As per the NBC Part IV, the number of occupants comes out to be approx 52 person's i.e. (93.64/1.8=52).

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/EH/2024/399 dated: 19.09.2024 have been complied by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules. It is recommended to renew Fire Safety certificate vide this department letter of even no. F6/DFS/MS/2021/338 Dated 22.11.2021.

D.B. Mukharjee (DO/NW)

[Handwritten signature]
02/10/2024
By CFO (102)

[Handwritten signature]
8/10

CFO
[Handwritten signature]
19/10/2024
Director

[Handwritten signature]
08/10/2024
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

DCFO... 436... MHA
Dated: 08/10/24

Received on
11/10/2024

[Handwritten signature]