

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/EH/WZ/2024/ 321

Dated: 10/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Taco Bell (A unit of Burman Hospitality Pvt. Ltd.)**, located at **Shop No. SH/2F/10, Second Floor, Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi-110018**, in Pacific Mall is comprised of Two Basements, Ground & four upper floors plus Projection room was issued FSC by this department vide letter no. F.6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023 & FSC issued to Taco Bell (A unit of Burman Hospitality Pvt. Ltd.), vide letter no. F6/DFS/MS/EH/MN/2021/305 dated 26/10/2021. The premises was re-inspected by the officer concerned of this department on 20/09/2024 in the presence of Ms. Shakshi (Manager) and observed that fire prevention and fire safety arrangements provided in the building found in good working condition. The building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D and valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on ...10/10/2024 at New Delhi by.


(Atul Garg)
Director

844
08/10/2024

Copy to:

1. The Owner/occupier/s. Taco Bell (A unit of Burman Hospitality Pvt. Ltd.), Shop No. SH/2F/10, Second Floor, Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi-110018,
2. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027. (dhowest zone@gmail.com)
3. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (addlcp.lic-dl@nic.in.)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building	Taco Bell (A unit of Burman Hospitality Pvt. Ltd.), located at Shop No. SH/2F/10, Second Floor, Pacific Mall, Tagore Garden, Najafgarh Road, New Delhi-110018.
2. Type of Occupancy	Assembly
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/MN/2021/305 dated 26/10/2021
5. Fire Safety directives letter No	Nil
6. Date of inspection	20/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Ms. Sakshi (Manager)
9. Year of Construction	2011 (As Per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2024090913975 dated 09/09/2024

The said restaurant is running at Second Floor in Pacific Mall is comprised of two basement, ground & four upper floors & projection room was issued FSC vide letter no. F.6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	6m	Provided	MR
2	Number, Width, Type & Arrangement of Exits (Common with the building)			
	a. Number of staircases			
	• Upper Floors	2	Provided by mall	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m each	Provided by mall	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	Required	Provided by Mall	MR
	g. Door Size	1.5m x 2	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	04 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.	(common with the mall)		
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.	(common with the mall)		
	• Type of detectors	Required	Smoke & Heat Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants	(common with the mall)		
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements	(common with the mall)		
	• Ground Level			
	➤ Discharge of main Pump	NA	Common with the mall	NA
	➤ Head of Main pump	NA	Common with the mall	NA
	➤ Number of main pumps	NA	Common with the mall	NA
	➤ Jockey Pump out put	NA	Common with the mall	NA
	➤ Jockey pump head	NA	Common with the mall	NA
	➤ Standby Pump out put	NA	Common with the mall	NA
	➤ Standby Pump Head	NA	Common with the mall	NA
	➤ Auto Starting/ Manual stopping	NA	Common with the mall	NA
	➤ Pump House Access	NA	Common with the mall	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the mall	MR
	➤ Head of the pump	40 m	Common with the mall	MR
	➤ Power Supply	Required	Common with the mall	MR
	➤ Auto Starting of pump	Required	Common with the mall	MR
14	Captive Water Storage for fire fighting.	(common with the mall)		
	• Underground tank capacity	NA	2,00,000 ltrs provided	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20, 000 ltrs	30, 000 Ltrs Provided	MR
15	Exit Signage.	Required	provided	MR

218

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

MR
MR
MR

295/ADO/MN
24/09/24

The fire protection systems provided in the building were checked & found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/MN/2021/305 dated 26/10/2021 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

24 CPO (w/2)

SS
24/9/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (Moti Nagar)

Sir it is a case of renewal & it is in Pacific Mall Khyala. F.S.C./NOC of mall is already done. And req. 2nd exit, it is reflected on poster. However due to light painting it is clearly not visible

resubmitted p/s

DCFO: 107
Dated: 30/9/2024

24 CPO (w/2)

CFO
01/10/2024

30/9
Director
1/10/24
Raj MR

SS
30/9/2024

Sir, F.T is put up for your kind personal & signature please.

~~Director~~
9/11/24
N

~~Signature~~
08/10/2024

Signature
10/10/24