

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2024 / 1057

Dated: 23/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Commercial Senior Secondary School** located at **24, Darya Ganj, Delhi - 02**, comprised of **ground + 02 upper floors + 01 Auditorium** was granted FSC by this department vide letter no.F6/DFS/MS/School/NDZ/2021/356 dated 04.05.2021. The premises/ building was re-inspected by the officer concerned of this department on 14.10.2024 in the presence of Mr. Naresh Kumar Sharma (In -Charge) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building is fit for occupancy of **(Group-B) "Educational Building", (Ground + 02 upper floors + 01 Auditorium)**, with effect from 23.10.24.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 23.10.24.....at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
ok  
2/10

**Copy to:-**

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Commercial Senior Secondary School at 24, Darya Ganj, Delhi - 02.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1	Name & address of the building	Commercial Senior Secondary School, 24, Darya Ganj, Delhi.		
2	Building is comprised of	(Ground + 02 upper floors)		
3	Type of Occupancy	Educational building (Academic block & 01 Auditorium)		
4	Type of Case	Renewal (old case)		
5	Details of Previous FSC	Nil		
6	Fire Safety direction letter No	F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated. 01.03.11		
7	Date of Inspection	14.10.2024		
8	Name of the Inspecting Officers	Sumit Kumar, ADO (SPM)		
9	Name of the designation of Officer from the building side	Mr. Naresh Kumar Sharma (In -Charge)		
10	Year of Construction	1961-62		
11	Applicant's letter No	Letter no. CSSS/2024/1058 dated 19.09.2024		
S. No	Minimum Standards on fire safety requirements as per circular no. F.16/Estate/fire safety/2011/3298-3398 dated 01.03.2011	Requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	06 m	08 m ✓	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	<b>A. Number of Staircases</b>			
	Upper Floor	01 no.	01 no. ✓	MR
	Basement	NA	NA	NA
	<b>B. Width of Staircases</b>			
	Upper Floor	1.5 m	2.0 m ✓	MR
	Basement	NA	NA	NA
	<b>C. Protection of exits</b>			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	<b>D. No. of continuous staircases to terrace</b>			
		01 no.	01 no. ✓	MR
	<b>E. Width of Corridor</b>			
		1.5 m	2.0 m ✓	MR
	<b>G. Door size</b>			
		1.0 m	1.0 m ✓	MR
3	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	Basement	NA	NA	NA
	Upper floor	12 ACPH	Natural	MR

6 8

<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	10 nos.	17 nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	Required	Provided	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	01 no.	01 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters	N.A	NA	NA
<b>8</b>	<b>MOEFA</b>	N.A	NA	NA
<b>9</b>	<b>Public address System.</b>	NA	Provided	NA
<b>10</b>	<b>Automatic Sprinkler System.</b>	<b>Provided in auditorium</b>		
	basement	NA	NA	NA
	upper floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	NA	03 nos.	NA
	Hose Box	NA	03 nos.	NA
<b>13</b>	<b>Pumping Arrangements.</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump for basement	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 Ltrs	10,000 Ltrs	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	NA	NA	NA
	Firemen's grounding switch	NA	NA	NA
	Lift Signage	NA	NA	NA
<b>17</b>	<b>Standby power supply</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area.</b>			
	Total area	NA	NA	NA
	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room</b>			
	Detector system panel	NA	NA	NA
	Flow switch panel	NA	NA	NA
	PA system panel	NA	NA	NA
	Batter backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the school were tested, checked at random found functional at the time of inspection.

Shortcomings communicated vide letter no. F6/DFS/MS/School/NDZ/2024/648 dated 20.09.2024 have been rectified.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required as per Director of Education Circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter in. F6/DFS/MS/School/NDZ/2021/356 dated 04.05.2021, renewal under rule 37 of the Delhi Fire Service rules 2010, is recommended.

*Sumit Kumar*  
15/10/2024

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO/CD)

*16/10/24*

*Dy. C.F.O. (NDZ)*

*18/10/24*

*C.F.O.*  
*18/10/2024*

*Director*

*12/11/24*

*ADO SPM*