



No. F6/DFS/MS/EH/SZ/2024/ 327

Dated: 14/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Haldiram Marketing Pvt. Ltd located at Shop no. 15, 2<sup>nd</sup> floor, Commercial Complex, 3Cs Mall, Firoz Gandhi Marg, Lajpat Nagar New, Delhi-24 was re-inspected by officer concerned of this department on 09.10.2024 in the presence of Mr. Gaurav (Manager) and it was found that this restaurant is running at a portion of 2<sup>nd</sup> floor of the mall building comprised of Two Tier Basement + Ground + 02 upper floors. The said portion of the building was earlier granted Fire Safety Certificate (FSC) in the name of Jungle Jamboree by this department vide letter no. F6/DFS/MS/EH/2019/SZ/1924 dated 09.10.2019. The restaurant has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building is fit for occupancy of Group D "Assembly Building" (Restaurant) and valid upto 31.03.2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....14/10/2024.....at New Delhi by

(Atul Garg)

Director

Delhi Fire Service

Reference: MHA Portal Online application no. 2024092614857.

**Conditions for the validity of Fire Safety Certificate**

1. This Fire Safety Certificate is valid only for restaurant at a portion of 2<sup>nd</sup> floor.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Basement shall be used as per NBC/UBBL.
10. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

**INSPECTION REPORT**

1.	Name and address of the building:	M/s Haldiram Marketing Pvt. Ltd located at Shop no. 15, 2 <sup>nd</sup> floor, Commercial Complex, 3Cs Mall, Firoz Gandhi Marg, Lajpat Nagar, New Delhi-24.
2.	Type of occupancy	Group D, "Assembly" (Restaurant at 2 <sup>nd</sup> floor of the building)
3.	Building comprised of	Two Tier Basement + Ground + 02 upper floors
4.	Type of case:	Renewal (Earlier FSC issued in the name of Jungle Jamboree)
5.	Details of previous FSC	F6/DFS/MS/EH/2019/SZ/1924 dated 09.10.2019
6.	Fire safety directives no	Nil
7.	Date of inspection:	09.10.2024
8.	Name of the inspecting officer:	Rajesh Kumar Shukla, ADO (M. Road)
9.	Name and designation of the officer from the building side:	Mr. Gaurav (Manager)
10	Year of construction:	2001
11	Reference letter no.:	MHA online application no.2024092614857

S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements As per Rule 35 (6)	Provide at site	Remarks MR/NMR
<b>1</b>	<b>Access to Building:</b>			
	<b>A</b> Road width	6.0 mtrs	9.0 mtrs	MR
	<b>B</b> Gate width	NA	NA	NA
	<b>C</b> Width of internal roads	NA	NA	NA
<b>2</b>	<b>Number, Width, Type &amp; Arrangement of Exits:</b>			
	<b>A</b> No. of Staircase:	Provided & maintained by building management		
	a) Upper floor	2 nos.	3 nos.	MR
	b) Basements	NA	NA	NA
	<b>B</b> Width of the Staircase:	Provided & maintained by building management		
	a) Upper floors			
	i) Main staircase	2.0 mtrs.	2.0 mtrs, 1.92 mtrs	MR
	ii) Atl. staircase	1.5 mtrs.	1.50 mtrs	MR
	b) Basements	NA	NA	NA
	<b>C</b> Protection of Exits	Provided & maintained by building management		
	a) fire check door	Required	Provided	MR
	b) pressurization	NA	NA	NA
	<b>D</b> No. of continuous staircase to terrace	Required	Provided	MR
	<b>E</b> Width of the corridor	1.5 mtrs.	Provided	MR
	<b>F</b> Door size			
	a) Main exits	2.0 mtrs.	Provided	MR
	b) Alternate exist	1.5 mtrs.	Provided	MR
<b>3</b>	<b>Compartmentation:</b> Horizontal open space between mall & restaurant			
	<b>A</b> Fire check doors	NA	NA	NA
	<b>B</b> Sealing of horizontal & vertical opening	NA	NA	NA
	<b>C</b> Fire rating of shaft doors	NA	NA	NA
	<b>D</b> Water curtain	NA	NA	NA
	<b>E</b> Fire dampers	NA	NA	NA
<b>4</b>	<b>Smoke management System:</b> Provided & maintained by building management			
	<b>A</b> Basements	30ACPH	Provided	MR
	<b>B</b> Upper floors	12 ACPH	Provided	MR
<b>5</b>	<b>Fire extinguishers:</b>			
	<b>A</b> Total numbers	Required	06 Nos.	MR
	<b>B</b> Types	ABC +CO <sub>2</sub>	ABC &CO <sub>2</sub>	MR
	<b>C</b> ISI marking	Required	Provided	MR

6	<b>First Aid Hose reel:</b>	Provided & maintained by building management		
	A Total no. at each floor	One near Restaurant	Provided	MR
	B Length of hose reel	30 mtrs.	Provided	MR
	C Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic Fire Detection and Alarm System (ADAS):</b>	Provided & maintained by building management		
	A Type of detectors	Smoke & heat	Smoke & heat	MR
	B Location of main panel	Required	Ground floor	MR
	C Location of repeater panel	NA	NA	NA
	D Alternate power source	NA	NA	NA
	E Hooter's location	All Area	Provided	MR
8	<b>MOEFA:</b>	Required	Provided	MR
9	<b>Public Address System:</b>	NA	NA	NA
10	<b>Automatic Sprinkler System:</b>	Provided & maintained by building management		
	A Basement	NA	NA	NA
	B Upper floor	Required	Provided	MR
	C Sprinklers above false ceiling	NA	NA	NA
11	<b>Internal Hydrants:</b>	Provided & maintained by building management		
	A Size of down comer	100 mm	150 mm	MR
	B No. of hydrants per floor	1 near Restaurant	Provided	MR
	C Hose box	1 near Restaurant	Provided	MR
12	<b>Yard Hydrants:</b>			
	A Total no. of hydrants	NA	NA	NA
	B Hose box	NA	NA	NA
13	<b>Pumping arrangements:</b>	Provided & maintained by building management		
	A Ground Level			
	a) Discharge & head of main pump	2280 LPM 60 mtrs	Provided	MR
	b) Number of main pump	Two	Provided	MR
	c) Discharge & head of jockey pump	180 LPM	Provided	MR
	d) Discharge & head of standby pump	2280 LPM 60 mtrs	Provided	MR
	e) Auto starting/ manual stopping	Required	Provided	MR
	B Terrace Level			
	a) Discharge of terrace pump	450 LPM	Provided	MR
	b) Head of terrace pump	40 mtrs	Provided	MR
	c) Alternate power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for Fire Fighting:</b>	Provided & maintained by building management		
	A Underground tank capacity	1,00,000 ltrs	Provided	MR
	B Draw off connection	NA	NA	NA
	C Fire service inlet	Required	Provided	MR
	E Access to tank	Required	Provided	MR
	D Overhead tank capacity	10,000 Liters	Provided	MR
15	<b>Exit Signage:</b>	Required	Provided	MR
16	<b>Provision of lift:</b>	Provided & maintained by building management		
	A Pressurization of lift shaft	NA	NA	NA
	B Pressurization of lift lobby	NA	NA	NA
	C Communication in lift car	NA	NA	NA
	D Fireman switch	NA	NA	NA
	E Lift signage	NA	NA	NA
17	<b>Standby Power Supply:</b>	Required	Provided	MR


M/s Haldiram Marketing Pvt. Ltd located at Shop no. 15, 2<sup>nd</sup> floor, Commercial Complex, 3Cs Mall, Firoz Gandhi Marg, Lajpat Nagar New Delhi-24.


<b>18 Refuge Area:</b>					
A	location	NA	NA	NA	NA
B	Total area	NA	NA	NA	NA
<b>19 Fire Control Room:</b>					
A	Fire detection system panel	NA	NA	NA	NA
B	Flow switch panel	NA	NA	NA	NA
C	P a system panel	NA	NA	NA	NA
D	Battery backup	NA	NA	NA	NA
E	Building floor plan	NA	NA	NA	NA
<b>20 Special Fire Protection for special risk if any</b>					
A	Special Fire Protection system for Protection of Special Risk, if any:				NA


**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide But Not Functional (PNF).**


The fire protection systems provided in the building were tested, checked at random and fire systems were found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/2019/SZ/1924 dated 09.10.2019 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

  
 Signature of the Inspecting Officer  
 Name : Rajesh Kumar Shukla  
 Designation ADO (M. Road)


DO (SD)  11/12/24

CFO (P&S)  11/12/2024


Director 

FT Ph

ADD/m.21

File upload  14/10/24

M.S. Cell

Uploaded  14/10/24