

C-121





GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F 6 / DFS / MS / 2023 / GH/WZ/ 411

Dated: 11/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Royal Mirage Guest House** located at **1st, 2nd & 3rd Floors of WZ- 107/ A-B, Rishi Nagar, Rani Bagh, Delhi-110034** in a building comprised of **Basement, Ground plus Three upper floors** was issued FSC by this department vide letter No F6/DFS/MS/GH/WZ/2021/321 dated 19.08.2021. The premise was re-inspected by the officer concerned of this department on 05.10.2024 in the presence of **Sh. Paras Kalra** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy "**Residential (Guest House)**" with effect from11.10.2024 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11.10.2024... at New Delhi, by


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Hotel Royal Mirage Guest House located at 1st, 2nd & 3rd Floors of WZ- 107/ A-B, Rishi Nagar, Rani Bagh, Delhi-110034.
2. MHA Portal, ID No. 2024092114563.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MHA portal (<https://www.delehlhlic.gov.in>) along with a copy of this Certificate, six months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. This FSC is only for guest house at 1st, 2nd & 3rd floor.

INSPECTION REPORT

- 1. Name & address of the building : Hotel Royal Mirage located at WZ- 107/ A-B, Rishi Nagar, Rani Bagh, Delhi-110034.
- 2. Type of Occupancy : Residential (Guest House at 1st, 2nd & 3rd floors).
- 3. Building Comprised of : Basement (Other Property), Ground (Reception) plus three Upper Floors.
- 4. Type of Case : Renewal
- 5. Details of Previous NOC : F6/DFS/MS/GH/WZ/2021/321 Dated 19/08/2021
- 6. Fire Safety directives letter No : Nil
- 7. Date of inspection : 05/10/2024
- 8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
- 9. Name and designation of officers
- 10. From the building side : Sh. Paras Kalra
- 11. Year of Construction : 2008 as per MHA Portal
- 12. Applicant's letter No. : MHA Application ID No. 2024092114563 dated 21/09/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL, Inspection report dated 17/08/2021	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	Provided	MR
	Gate width	4.5 m	On Road	MR
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	02	02	MR
	Basements	02	Provided	MR
	Width of staircases			
	Upper Floor	1.5 m each	1.15 m & 0.99 m	MR(old case)
	Basements	1.5 m each	1.32 m & 1.20 m	MR(old case)
	Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	01	01	MR
	Width of Corridor	NA	NA	NA
	Door Size	1 m	Provided	MR
3.	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	Required	Provided	MR
	Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	Total numbers	10 Nos.	14 Nos.	MR
	Types	ABC/Co2 Type	Provided	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	Type of detectors	CO	Provided	MR
	Location of Main Panel	Required	Provided	MR
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	Required	Provided	MR

(Handwritten signature)

	Hooters' Location	Near Staircase	Provided	
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	Basement	Required	Provided	MR
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	NA	100 mm	NA
	Number of hydrants per floor	NA	01	NA
	Hose Box	NA	01	NA
12.	Yard Hydrants			
	Total number of hydrants	NA	01	NA
	Hose Box	NA	01	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	900 lpm	450 lpm × 2, Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	Required	Provided	MR
	Fireman's Grounding Switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			

N-41

Detector System Panel	NA	NA	NA
Flow Switch Panel	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F6/DFS/MS/WZ/2024/GH/329 dated 12/06/2024.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the fire safety certificate issued vide letter no. F6/DFS/MS/GH/WZ/2021/321 dated 19/08/2021 under rule 37 of the Delhi Fire Service Rules, 2010.

(Signature)
21/10/24

Signature of Inspecting Officer
Name : Rajeew Kumar Sinha
Designation : ADO/B.W.

Dy Cfo/102 - OMM/R

Cfo 11/10/24
10/10/2024
Director 11/10/24

(Signature) *(Signature)*

14/10/24
(Signature)