

C/47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/Educational/2024/SZ/ 47

Dated: 23/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Property No. A-1/22, Janakpuri, New Delhi- 110058**, comprised of basement (sealed by MCD), stilt (parking), upper ground, 1st & 2nd floor (Coaching Center), owned/occupied by **M/s. Aakash Educational Services Limited** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officers concerned of this department on 17.10.2024 in the presence of Sh. Abhay Srivastav, and found that the building is fit for occupancy class "**Educational Building**" (at upper ground, 1st & 2nd floor only) with effect from 23/10/2024 for a period of **three** years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 23/10/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Authorized Signatory, Property No. A-1/22, Janakpuri, New Delhi- 110058.
2. Executive Engineer (Bldg.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027.

: - for information as basement found sealed by MCD

Conditions for validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Use of the basement will only be allowed after de-sealing and permission from MCD, w.r.t. use and prior approval of this department from fire safety point of view.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Property No. A-1/22, Janakpuri, New Delhi-110058.
2. Building is comprised of : Basement (Sealed by MCD), Stilt (Parking), upper ground, 1st & 2nd floor (Coaching center)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous FSC : Nil
6. Fire Safety directives letter no. : Nil
7. Date of Inspection : 17.10.2024
8. Name of the Inspecting officers : Vedpal Chhikara, DO (SW) & R.K. Yadav, ADO (JKP)
9. Name and designation of
Officer from the building side : Sh. Abhay Srivastav
10. Year of Construction : 2018-19
11. Applicant's letter No : Letter No. Nil, dated 26.09.2024

D-684/EC(BS)-11/N2/302/AES
23.9.2024

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 m N/A N/A	Provided N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 Nos. N/A	03 Nos. N/A	MR Basement sealed
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M each N/A	1.5 m (02 no's) & 1.25 M N/A	MR Basement sealed <i>(By MCD)</i>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	1.5 m	1.50 & 1.80 m	MR
	f. Door Size	1.20 m	1.20 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	Required Required N/A N/A N/A	Provided Sealed N/A N/A N/A	MR MR N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A Required	N/A Natural ventilation	Basement sealed MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	20 Nos. ABC & Co2 ISI marked	20 Nos. ABC & Co2 ISI marked	MR MR MR


6	First-aid-Hose Reels.			
	Total numbers of each floor	2 Nos. <i>h</i>	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 MM	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement (sealed)/Stilt	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 Nos.	Provided	MR
	• Hose Box	01 No	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level each block			
	➤ Discharge of pump	900 LPM	1680 LPM & 450 LPM	MR
	➤ Head of the Pump	40 M <i>h</i>	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 Ltrs <i>h</i>	20,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			


	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required	LT & HT panel provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.





Note: - As per undertaking given by the management of Institute (placed at C-39) that the basement of the building was sealed by the MCD and they will inform this department prior to using basement after de-sealing by the MCD.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule, 2010.


 Signature of the Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)


 Signature of the Inspecting Officer
 Name: - Vedpal Chhikara
 Designation: - DO (SW)

CFO (SZ)


 Director

 ADO (SW) Puri

 ADO (SW) Puri

 ADO (SW) Puri