

e 75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 440

Dated: 28/10/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Ejaz Guest House situated at 4177, Main Urdu Bazar, Jama Masjid, Delhi - 06, comprised of Ground + 04 upper floors: Ground floor - (commercial use), 1st floor - (reception + 01 hall with 04 beds), 2nd floor - (01 guest room + 01 hall with 04 beds), 3rd floor - (01 guest room + 01 hall with 04 beds) & 4th floor- (not in use), total 02 guest rooms + 03 hall with 12 beds was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2021/473 dated 22.10.2021. The building/premises was re-inspected by officer concerned of this department on 18.10.2024 in presence of Mohd. Maqsood Alam (Manager) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The owner has submitted an affidavit on 21.10.2024 stating not to use any floor above third floor for any purpose. Accordingly, the premises is fit for occupancy of (Group-A-1) "Residential", 1st floor - (01 hall with 04 beds), 2nd floor - (01 guest room + 01 hall with 04 beds) & 3rd floor - (01 guest room + 01 hall with 04 beds) for total 02 guest rooms + 03 hall with 12 beds upto 3rd floor only with effect from28/10/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 subject to condition printed below.

Issued on28/10/2024.....at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000
9/10/2024

Copy to:-

1. The Commissioner, MCD:- to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2024100815429 dated 08.10.2024.
3. The Licensee, M/s Ejaz Guest House at 4177, Main Urdu Bazar, Jama Masjid, Delhi - 06.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. The occupancy of above 3rd floor not allowed as per clause 7.31 in UBBL-2016.

INSPECTION REPORT

1	Name & address of the building	M/s Ejaz Guest House at 4177, Main Urdu Bazar, Jama Masjid, Delhi - 06.		
2	Building is comprised of	Ground + 04 upper floors Ground floor – (commercial use) 1 st floor – (reception + 01 hall with 04 beds) 2 nd floor – (01 guest room + 01 hall with 04 beds) 3 rd floor – (01 guest room + 01 hall with 04 beds) 4 th floor- (not in use as per affidavit dated 21.10.2024)		
3	Type of occupancy	Residential Group A-1		
4	Type of case	Renewal (old case)		
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2021/473 dated 22.10.2021		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	18.10.2024		
8	Name of the inspecting officers	Sumit Kumar, ADO (SPM)		
9	Name of the designation of officer from the building side	Mohd. Maqsood Alam (Manager)		
10	Year of construction	1992		
11	Applicant's letter no.	Online application no. 2024100815429 dated 08.10.2024		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	NA (special area)	12 m	NA
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
	a	Upper floor	01 no.	01 no. ✓
	b	Basement	NA	NA
B	Width of staircases			
	a	Upper floor	80 cms. (special area)	100 cms. ✓
	b	Basement	NA	NA
C	Protection of exits			
	a	Fire check door	NA	NA
	b	Pressurization	NA	NA
D	No. of continuous staircases to terrace		01 no.	01 no.
E	Width of corridor		NA	NA
F	Door size		0.80 mtr.	1.0 mtr. ✓
3	Compartmentation:			
A	Fire check door		NA	NA
B	Sealing of electrical shafts		NA	NA
C	Fire raiing of shaft door		NA	NA
D	Water curtain		NA	NA
E	Fire dampers		NA	NA
4	Smoke Management System:			
A	Upper floors		12 ACPH	Natural
B	Basements		NA	NA

5.	Fire Extinguisher:				MR
	A	Total numbers	06 nos.	06 nos.	MR
	B	Types	CO ₂ & ABC	Provided	MR
	C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reels:				MR
	A	Total numbers of each floor	01 no.	01 no. (1 st & 3 rd floor) (cover 2 nd floor)	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection And Alarming System:				MR
	A	Type of detectors (CO type)	Required	Provided	MR
	B	Location of main panel	Required	Provided at reception	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	Required	Provided	MR
8	MOEFA:		NA	NA	NA
9	Public Address System:		Required	Provided	MR
10	Automatic Sprinkler System:				NA
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				NA
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				NA
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				MR
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	225 LPM	225 LPM	MR
	b)	Head of the pump	30 m	30 m	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	2,500 ltrs.	2,500 ltrs. ✓
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at randomly and found functional at the time of inspection.

The owner has submitted an affidavit on 21.10.2024 stating not to use any floor above third floor for any purpose.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No F6/DFS/MS/GH/NDZ/2021/473 dated 22.10.2021 is recommended to be renewed upto 1st to 3rd floor only, under Rule 35 of the Delhi Fire Service Rules 2010.

Sumit Kumar
21/10/2024

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (CD)

[Signature]
22/10/24

[Signature]
C.F.O.

[Signature]
22/10/24

[Signature]
23/10/2024
Director

[Signature]
ADO/SPM