

No. F6/DFS/MS/EH/WZ/2024/354

Dated:- 28/10/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Haldiram Products Pvt. Ltd., Located at Ground Floor (Shop no. 6, 7 & 8) and First Floor (Shop no. 106), ARSS Felix, Plot no. 40, Block-A, Community Centre, Paschim Vihar, Delhi-110063, is running at Ground Floor (Shop no. 6, 7 & 8) and First Floor (Shop no. 106) in a building comprised of 03 Basement + Ground + 04 Upper Floors only owned/occupied by M/s. Haldiram Products Pvt. Ltd., was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/SZ/2021/348 Dated 30/11/2021. The said premise was re-inspected by the officer concerned of this department on 09/10/2024 in the presence of Sh. Chandra Mohan (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" Group D with effect from 28/10/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 28/10/2024 at New Delhi by.

(Anil Garg)
Director

Tel. No. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. Sh. Madhusudan Aggarwal, M/s. Haldiram Products Pvt. Ltd., Ground Floor (Shop no. 6, 7 & 8) and First Floor (Shop no. 106), ARSS Felix, Plot no. 40, Block-A, Community Centre, Paschim Vihar, Delhi-110063.

Following fire safety directives must be adhered to:-

1. This FSC is valid for restaurant area's Ground Floor (Shop no. 6, 7 & 8) and First Floor (Shop no. 106) only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Haldiram Products Pvt. Ltd. located at Shop No. 6, 7 & 8 (Ground Floor) and Shop No. 106 (First Floor), ARSS Felix Mall, Plot No. 40 Block-A, Community Centre, Paschim Vihar, Delhi-110063
2. Type of Occupancy : Assembly, (Restaurant at G.F-Shop no. 6,7&8 and F.F-Shop no. 106)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/SZ/2021/348 dated 30/11/2021
5. Fire Safety directives letter No : As per UBBL/NBC (Part-IV)
6. Date of inspection : 09/10/2024
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of officers from the building side : Sh. Chandra Mohan (Manager)
9. Year of Construction : 2014 (as per details upload on MHA portal)
10. Applicant's Online ID- : 2024092814963 dated 28/09/2024

The said restaurant is running at Ground Floor & First Floor only, in a building comprised of 03 Basement + Ground Plus 04 Upper Floors only.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC-IV requirements/as per FSC dated 30/11/2021	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	30 m	MR
	• Gate width	4.5 m	06 m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	03	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 m & 1.0 m	1.5 m x 2 1.2 m x 1	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 m x 1 & 1.0 m x 1	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

2-27

4	Smoke Management System.			
	• Basements	NA	N/A	N/A
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	04 Nos.	Provided	MR
	• Types	ABC, CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels. (Common with the ARSS Mall)			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided by mall	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants (Common with the ARSS Mall)			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements (Common with the ARSS Mall)			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	Provided by mall	N/A
	➤ Head of Main pump	N/A	Provided by mall	N/A
	➤ Number of main pumps	N/A	Provided by mall	N/A
	➤ Jockey Pump out put	N/A	Provided by mall	N/A
	➤ Jockey pump head	N/A	Provided by mall	N/A
	➤ Standby Pump out put	N/A	Provided by mall	N/A
	➤ Standby Pump Head	N/A	Provided by mall	N/A
	➤ Auto Starting/ Manual stopping	N/A	Provided by mall	N/A
	➤ Pump House Access	N/A	Provided by mall	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	900 lpm	Provided by mall	MR
	➤ Head of the pump	40 m	Provided by mall	MR
	➤ Power Supply	Required	Provided by mall	MR
	➤ Auto Starting of pump	Required	Provided by mall	MR

Captive Water Storage for fire fighting		(Common with the ARSS Mall)		
<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	Provided by mall	N/A	
	N/A	Provided by mall	N/A	
	N/A	Provided by mall	N/A	
	N/A	Provided by mall	N/A	
	10,000 ltrs.	Provided by mall	MR	
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A	
	N/A	N/A	N/A	
19	Fire Control Room			
<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/SZ/2021/348 dated 30/11/2021 is recommended under Rule 37 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Accordingly DFA is put up for approval please.

Aman Kumar Lathar
Aman Kumar Lathar
ADO (JWP)

DCFO (W2)

[Signature]
23/10

DCFO/.....
Dated.....23/10/24.....

CFO
[Signature]
24/10/2024
Director

[Signature]
P.F.O.