



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/1078

Dated: 29/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Kripa School** located at Sadar Bazar, Delhi Cantt, New Delhi-110010, comprised of ground floor only, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2019/SZ/1760 dated 12/09/2019. The premise was re-inspected by the officer concerned of this department on dated 21/10/2024 in the presence of Harsh Sharma (Supervisor) of the school and found the fire safety arrangements in satisfactory working condition. Therefore, said premises/building have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-B** (Educational) with effect from 29/10/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/10/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Sh. Kapil Goyal, Office of the Delhi Cantonment Board Model School, Sadar Bazar, Delhi Cantt., New Delhi-110010
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N/6

| INSPECTION REPORT | | | | |
|-------------------|---|---|-----------------------|----------------|
| 1. | Name & address of the building | Kripa School located at Sadar Bazar, Delhi Cantt, New Delhi- 110010 | | |
| 2. | Type of Occupancy | Educational (Group-B) | | |
| 3. | Building Comprised of | Ground floor only | | |
| 4. | Type of Case | Renewal | | |
| 5. | Details of previous NOC No. | F.6/DFS/MS/School/2019/SZ/1760 dt.12/09/19 | | |
| 6. | Fire Safety directives Letter No. | Nil | | |
| 7. | Date of inspection | 21/10/2024 | | |
| 8. | Name of the Inspecting Officer | ADO (SJ) | | |
| 9. | Name and designation of Officer from the building side | Mr. Harsh Sharma (Supervisor) | | |
| 10. | Year of Construction | 2017 | | |
| 11. | Applicant's letter No. | Outdoor diary No. 7540 dated 08/10/2024 | | |
| S. No. | Minimum standards on fire prevention and fire safety U/R 33 | Old NOC Requirement | Provided at site | Remarks MR/NMR |
| 1. | Access of building | | | |
| | • Road width | 6m | 9m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.20m | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 08 Nos | Provided | MR |
| | • Types | ABC/CO ₂ | ABC & CO ₂ | MR |
| | • ISI marking | ISI Marked | Provided | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |

N/7

| | | | | |
|-----|--|----|----|----|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down- comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw of connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage | | | |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | | | |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |

11

N/8

| | | | | |
|-----|--|----|----|----|
| 19. | Fire Control Room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of Special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2019/SZ/1760 dated 12/09/2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S Kumar
29/10/20

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD) *[Signature]*

CFO (MS)
[Signature]
25/10/2020

Director
[Signature]
28/10/20
ADP/SJ

Sir,
F.T letter is put up for your sig. p

Director
[Signature]
29/10/20

S Kumar
28/10/20