

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/ 431

Dated: 23/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Oasis Guest House situated at 3745, Kucha Parmanand, Darya Ganj, New Delhi - 02, comprised of Ground + 03 upper floors: Ground floor - (reception), 1<sup>st</sup> floor - (05 guest rooms), 2<sup>nd</sup> floor - (05 guest rooms) & 3<sup>rd</sup> floor - (04 guest rooms + staff room), total 14 guest rooms was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2021/417 dated 24.09.2021. The building/premises was re-inspected by officer concerned of this department on 15.10.2024 in presence of Mohd. Mirza Salim Beg (Owner) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of (Group-A-1) "Residential", 1<sup>st</sup> floor - (05 guest rooms), 2<sup>nd</sup> floor - (05 guest rooms) & 3<sup>rd</sup> floor - (04 guest rooms) for total 14 guest rooms upto 3<sup>rd</sup> floor only with effect from .....23/10/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 subject to condition printed below.

Issued on .....23/10/2024.....at New Delhi by

(Atul Garg)  
 Director

Delhi Fire Service o/c  
 Tel 011-23414000

**Copy to:-**

1. The Joint Commissioner of Police (Licensing), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2024100415199 dated 04.10.2024.
2. The Licensee, M/s Oasis Guest House at 3745, Kucha Parmanand, Darya Ganj, New Delhi - 02.

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

## INSPECTION REPORT


1	Name & address of the building	M/s Oasis Guest House at 3745, Kucha Parmanand, Darya Ganj, New Delhi.			
2	Building is comprised of	Ground + 03 upper floors Ground floor – (reception), 1 <sup>st</sup> floor – (05 guest rooms) 2 <sup>nd</sup> floor – (05 guest rooms) 3 <sup>rd</sup> floor – (04 guest rooms + staff room)			
3	Type of occupancy	Residential Group A-1			
4	Type of case	Renewal (old case)			
5	Details of previous FSC	F6/DFS/MS/GH/NDZ/2021/417 dated 24.09.2021			
6	Fire safety direction letter no.	Nil			
7	Date of inspection	15.10.2024			
8	Name of the inspecting officers	Sumit Kumar, ADO (SPM)			
9	Name of the designation of officer from the building side	Mohd. Mirza Salim Beg (Owner)			
10	Year of construction	2002			
11	Applicant's letter no.	Online application no. 2024100415199 dated 04.10.2024			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site (PSS)	Remarks MR/ NMR	
1	<b>Access To Building:</b>				
	Road width	06 m	15 m ✓	MR	
	Gate width	NA	NA	NA	
	Width of internal road	NA	NA	NA	
2	<b>Number, Width, Type and Arrangement of Exits:</b>				
A	Number of staircases				
	a	Upper floor	01 no.	01 no. ✓	MR
	b	Basement	NA	NA	NA
B	Width of staircases				
	a	Upper floor	80 cms.	105 cms. ✓	MR
	b	Basement	NA	NA	NA
C	Protection of exits				
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace				
			01 no.	01 no. ✓	MR
E	Width of corridor				
			NA	NA	NA
F	Door size				
			1.0 mtr.	1.0 mtr. ✓	MR
3	<b>Compartmentation:</b>				
A	Fire check door				
			NA	NA	NA
B	Sealing of electrical shafts				
			NA	NA	NA
C	Fire rating of shaft door				
			NA	NA	NA
D	Water curtain				
			NA	NA	NA
E	Fire dampers				
			NA	NA	NA
4	<b>Smoke Management System:</b>				
A	Upper floors				
			12 ACPH	Exhaust fan	MR
B	Basements				
			NA	NA	NA

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	08 nos.	08 nos.	MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	Provided	MR
	<b>C</b>	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reels:</b>				
	<b>A</b>	Total numbers of each floor	01 no.	01 no. ✓	MR
	<b>B</b>	Length of hose reel hose	30 m	30 m	MR
	<b>C</b>	Nozzle diameter	05 mm	05 mm ✓	MR
<b>7</b>	<b>Automatic Fire Detection And Alarming System:</b>				
	<b>A</b>	Type of detectors (CO type)	Required	Provided ✓	MR
	<b>B</b>	Location of main panel	Required	Provided at reception ✓	MR
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	Required	Provided	MR
	<b>E</b>	Hooters	Required	Provided	MR
<b>8</b>	<b>MOEFA:</b>		NA	NA	NA
<b>9</b>	<b>Public Address System:</b>		Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
	<b>A</b>	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	<b>B</b>	Terrace level			
	a)	Discharge of pump	225 LPM	225 LPM ✓	MR
	b)	Head of the pump	30 m	30 m ✓	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR


<b>14</b>	<b>Captive Water Storage For Fire Fighting:</b>				
	<b>A</b>	Underground tank capacity	NA	NA	NA
	<b>B</b>	Draw-off connection	NA	NA	NA
	<b>C</b>	Fire service inlet	NA	NA	NA
	<b>D</b>	Access to tank	NA	NA	NA
	<b>E</b>	Overhead tank capacity	2,500 ltrs.	2,500 ltrs.	MR
<b>15</b>	<b>Exit Signage:</b>		Required	Provided	MR
<b>16</b>	<b>Provision of Lifts:</b>				
	<b>A</b>	Pressurization of lift shaft	NA	NA	NA
	<b>B</b>	Pressurization of lift lobby	NA	NA	NA
	<b>C</b>	Communication in lift car	NA	NA	NA
	<b>D</b>	Firemen's grounding switch	NA	NA	NA
	<b>E</b>	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply:</b>		Required	Provided	MR
<b>18</b>	<b>Refuge Area:</b>				
	<b>A</b>	Total area	NA	NA	NA
	<b>B</b>	Location	NA	NA	NA
<b>19</b>	<b>Fire Control Room :</b>				
	<b>A</b>	Detector system panel	NA	NA	NA
	<b>B</b>	Flow switch panel	NA	NA	NA
	<b>C</b>	Pa system panel	NA	NA	NA
	<b>D</b>	Battery backup	NA	NA	NA
	<b>E</b>	Building floor plans	NA	NA	NA
<b>20</b>	<b>Special Fire Protection Systems For Protection of Special Risks, If Any:</b>		NA	NA	NA

The fire protection systems provided in the building were tested, checked at randomly and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No F6/DFS/MS/GH/NDZ/2021/417 dated 24.09.2021 is recommended to be renewed upto 3<sup>rd</sup> floor only, under Rule 35 of the Delhi Fire Service Rules 2010.


  
 15/10/2024  
 Signature of the Inspecting Officer  
 Name Sumit Kumar  
 Designation ADO (SPM)


DO (CD)


  
16/10/24

  
Dy. C.F.O. (P.2)

  
18/10/24

  
C.F.O.

  
18/10/2024

  
10/10/24

  
A. G. S. K.