



No.F6/DFS/MS/School/NDZ/2024/1082

Dated: 30/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya located at C - Block, Dilshad Garden, Delhi - 110095, building comprised of ground plus three upper floors in two blocks owned / occupied by Sarvodaya Kanya Vidyalaya, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2018/118 dated 22.01.2018. The School building was re-inspected by the officer concerned of this department on 16/10/2024 in presence of Mrs. Freda J. Baxla (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service, 2010 and observed that the school building is fit for ground plus three upper floors in two blocks occupancy class "B" Educational Building with effect from 30/10/2024 for a period of three years in accordance with the rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed bellow.

Note:-This Fire Safety Certificate does not cover the old building blocks for which shortcoming were issued vide letter No.F6/DFS/MS/School/2016//1411 dated 01/06/2016.

Issued on 30/10/2024 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. The Dy. Director of Education, B – Block, Yamuna Vihar, Delhi – 110053.
2. The Assistant Engineer (E), PWD Education, M1 Sub Division-IV, ITI Campus Pusa, New Delhi - 110012.
3. The Principal, Sarvodaya Kanya Vidyalaya located at C- Block, Dilshad Garden, Delhi - 110095.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1	Name & address of the building	Sarvodaya Kanya Vidyalaya located at C-Block, Dilshad Garden, Delhi-110095.		
2	Building is comprised of	Ground plus three upper floors.(New building block)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2018/118 dated 22.01.2018		
6	Fire safety directives letter no.	F16/DFS/MS/BP/2001/2475 dated 08/11/2001		
7	Date of inspection	16/10/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Freda J. Baxla (Principal)		
10	Year of construction	2017		
11	Applicant's letter no.	Outdoor Dairy No. 7610 dated 08/10/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	6.0 mtrs.	06 mtrs. ✓	MR
B	Gate width	4.50 mtrs	4.50 mtrs ✓	MR
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	01 + 01 no	02 nos ✓	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs.	1.68 mtrs each ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 nos.	02 nos. ✓	MR
E	Width of corridor	1.50mtrs.	1.75 mtrs. ✓	MR
F	Door size	1.10 mtrs.	1.10 mtrs. ✓	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

<b>5.</b>	<b>Fire Extinguisher:</b>			
A	Total numbers	12 nos.	12 nos. ✓	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
<b>6.</b>	<b>First-Aid-Hose Reel:</b>			
A	Total numbers of each floor	01 nos.	01 nos. ✓	MR
B	Length of hose reel hose	30 mtrs	30 mtrs ✓	MR
C	Nozzle diameter	5 mm	5 mm ✓	MR
<b>7.</b>	<b>Automatic Fire Detection and Alarming System:</b>			
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA:</b>			
		N/A	N/A	N/A
<b>9.</b>	<b>Public Address System:</b>			
		N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants:</b>			
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box (Total)	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants:</b>			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangements:</b>			
<b>1.</b>	<b>Ground level</b>			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2.</b>	<b>Terrace Level</b>			
A	Discharge of pump	450 LPM	450 LPM x 2 ✓	MR
B	Head of the pump	40 mtrs	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR


w

✓

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
	<b>A</b>	Underground tank capacity	N/A	N/A
	<b>B</b>	Draw-off connection	N/A	N/A
	<b>C</b>	Fire service inlet	N/A	N/A
	<b>D</b>	Access to tank	N/A	N/A
	<b>E</b>	Overhead tank capacity	10,000 ltrs.	10,000 ltrs. ✓
			Required	Provided
<b>15</b>	<b>Exit Signage:</b>			
<b>16</b>	<b>Provision of Lifts:</b>			
	<b>A</b>	Pressurization of lift shaft	N/A	N/A
	<b>B</b>	Pressurization of lift lobby	N/A	N/A
	<b>C</b>	Communication in lift car	N/A	N/A
	<b>D</b>	Firemen's grounding switch	N/A	N/A
	<b>E</b>	Lift signage	N/A	N/A
<b>17</b>	<b>Standby Power Supply:</b>			
<b>18</b>	<b>Refuge Area:</b>			
	<b>A</b>	Total area	N/A	N/A
	<b>B</b>	Location	N/A	N/A
<b>19</b>	<b>Fire Control Room:</b>			
	<b>A</b>	Detector system panel	N/A	N/A
	<b>B</b>	Flow switch panel	N/A	N/A
	<b>C</b>	PA system panel	N/A	N/A
	<b>D</b>	Battery backup	N/A	N/A
	<b>E</b>	Building floor plans	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			


The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/2021/NDZ/367 dated 26/07/2021 by this department have been rectified by the management.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the Fire Safety Certificate issued vide letter F6/DFS/MS/School/2018/118 dated 22.01.2018 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

  
18/10/2024

Signature of the Inspecting Officer  
Name Yashwant Singh Meena  
Designation ADO (L.N)

~~DY. CFO/NDZ~~

  
28/10/24

~~C.F.O~~

  
28/10/2024  
~~Director~~  




P.T.O