



No. F6/DFS/MS/DMRC/NDZ/2024/ 666

Dated: 04/11/2024 c41

FIRE SAFETY CERTIFICATE

Certified that the M/s Gokulpuri Elevated Metro Station Building, Gokulpuri, Line - 7, Delhi - 110094, building comprised of ground level, first commercial level, concourse level and platform level, owned/occupied by Delhi Metro Rail Corporation was issued Fire Safety Certificate vide letter No. F6/DFS/MS/DMRC/2021/NDZ/31 dated 20/01/2022. The Metro Station building was re-inspected by the officer concerned of this department on 15/10/2024 in the presence of Mr. Sanyam Jain (AM/Fire) and found that the Metro Station building have deemed complied with the fire prevention and Fire Safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for ground, first commercial level, concourse level and platform level occupancy class **Group D - 7 "Assembly Building"** with effect from 04/11/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to conditions printed below.

Issued on 04/11/24 at New Delhi by.

(ATUL GARG)
DIRECTOR

OK DELHI FIRE SERVICE

Copy to:-

1. Mr. Rajesh Aggarwal, GM/E&M, Metro Bhawan, Fire Brigade Lane, New Delhi - 110001.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Gokulpuri Elevated Metro Station Building, Gokulpuri, Line-7, Delhi - 110094.		
3	Type of occupancy	Assembly Building Road level (GF), First commercial level plus concourse level plus platform level.		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/DMRC/2021/NDZ/31 dated 20/01/2022		
6	Fire safety directives letter no.	F6/DFS/MS/BP/2013/167 dated 03/07/2013.		
7	Date of inspection	15/10/2024.		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Sanyam Jain (AM/Fire)		
10	Year of construction			
11	Applicant's letter no.	Outdoor dairy no. 7744 dated 11.10..2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	As per Directive Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	7.5 mtrs, wide main road.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	06 nos.	06 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	06 meters.	(4.0 meters x 04 nos.) (2.70 m x 02 nos.) (02 no. Escalators ground to concourse) (02 no. Escalators Concourse to plat form)	MR (50% cap. of Escalators is counted for Evacuation in NFPA)
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	N/A	N/A	N/A
E	Width of corridor	1.50 meters	1.50 meters	MR
F	Door size	2.0 meters	2.0 meters & 1.50 meters	MR
3	Compartmentation:			
A	Fire check door	Required	Provided	MR
C	Sealing of electrical shafts	Required	Provided	MR
D	Fire rating of shaft door	02 hrs	02 hrs	MR
E	Water curtain	N/A	N/A	N/A
F	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	Required	Natural Ventilated	MR

5.	Fire Extinguisher:				
	A	Total numbers	28 nos.	28 nos. /	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	(03 nos. concourse level) (04 nos. platform level)	(03 nos. concourse level) (04 nos. platform level) /	MR
	B	Length of hose reel hose	45 mtrs.	45 mtrs. /	MR
	C	Nozzle diameter	6.50 mm	6.50 mm /	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	Smoke / Heat	Smoke	MR
	B	Location of main panel	Required	Provided concourse level (station control room)	MR
	C	Location of repeater panel	Required	concourse level	MR
	D	Alternate source of power	Battery & DG set	Provided	MR
	E	Hooter's	Required	Provided	MR
8	MOEFA:		Required	Provided	MR
9	Public Address System:		Required	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per Branch	(03 nos. concourse level) (04 nos. platform level)	(03 nos. concourse level) (04 nos. platform level) /	MR
	C	Hose box	As above	As above	MR
12	Yard Hydrants:				
	A	Total number of hydrants	02 nos.	02 nos. /	MR
	B	Hose box	02 nos.	02 nos. /	MR
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	2850 LPM	2850 LPM /	MR
	B	Head of main pump	70 mtrs.	70 mtrs. /	MR
	C	Number of main pumps	01 no.	01 no.	MR
	D	Jockey pump out put	180 LPM	180 LPM /	MR
	E	Jockey pump head	70 mtrs	70 mtrs /	MR
	F	Standby pump out put	2850 LPM	2850 LPM	MR
	G	Standby pump head	70 mtrs.	70 mtrs. //	MR
	H	Auto starting /manual stopping	Auto	Provided	MR
	I	Pump house access	Required	Provided	MR
2	Terrace Level				
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	1,00,000 liters.	1,00,000 liters	MR
B	Draw-off connection	Required	Provided	MR
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	10,000 liters	10,000 liters	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	Required	Provided	MR
D	Firemen's switch	Required	Provided	MR
E	Lift signage	Required	Provided	MR
17 Standby Power Supply:		Required	Provided	MR
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	Required	Provided	MR
B	Flow switch panel	Required	Provided	MR
C	PA system panel	Required	Provided	MR
D	Battery backup	Required	Provided	MR
E	Building floor plans	Required	Provided	MR
20 Special Fire Protection System for Protection of special Risks, if any:		Required	NOVEC 1230 clean agent	MR

The fire protection systems provided in the building were randomly tested/checked and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety required under the Directive No. F6/DFS/MS/DMRC/2021/NDZ/31 dated 20/01/2022 issued by this department, it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. This certificate not applicable of P.D. area.

No File is pending with me before disposal of this case.

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO/Laxmi Nagar

~~DY. CFO/NDZ~~

~~C.F.O.~~

~~Director~~

P.T.D