



FIRE SAFETY CERTIFICATE

Certified that the DAV Public School, located at Sreshtha Vihar, Delhi - 110092, building comprised of basement (Store), ground plus three upper floors, owned/occupied by DAV Public School was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/960 dated 25/11/2021. The School building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 19/09/2024 in presence of Mrs. Suhasini Khushinder Nath (Principal) & Mr. Manoj Gupta (Superintendent) and that the school building is fit for occupancy class Group - B "Educational Building" for ground plus three upper floors only with effect from 04/11/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 & also conditions printed overleaf.

Issued on 04/11/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Joint Director of Education (Land & Estate) Delhi, Director of Education, Lucknow Road, Delhi - 110054.
2. The Principal, DAV Public School, located at Sreshtha Vihar, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground plus three upper floors only.
2. Presently basement is being used for storage purpose only.
3. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
4. All the means of escape shall be kept free of all the type of obstruction all the time.
5. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
6. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
7. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. At the time of inspection basement is being used for storage purpose.
10. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/22

INSPECTION REPORT

1	Name & address of the building	D.A.V Public School located at Sreshtha Vihar, Delhi - 110092.		
2	Building is comprised of	Basement (Store), ground plus three upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/960 dated 25/11/2021		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	23/09/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (Laxmi Nagar)		
9	Name of the designation of officer from the building side	Mrs. Suhasini Khushinder Nath (Principal)		
10	Year of construction	1989		
11	Applicant's letter no.	Outdoor Dairy No. 6461 dated 13/09/2024		
S. No	Minimum standard of fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building:			
A	Road width	6.0 mtrs.	10 mtrs.	MR
B	Gate width	4.5 mtrs	6.0 mtrs.	MR
C	Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	05 nos.	05 nos.	MR
	Basement	02 nos.	02 nos.	MR
B	Width of staircases			
a	Upper floor	1.5 mtrs.	1.5 mtrs, 1.5 mtrs, 1.5 mtrs, 1.25 mtrs & 1.10 mtr.	MR (Accepted earlier)
	Basement	1.5 mtrs.	1.70 mtrs, & 1.20 mtrs.	MR (Accepted earlier)
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 nos.	02 nos.	MR
E	Width of corridor	1.5 mtrs	2.40 mtrs	MR
F	Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4.	Smoke Management System:			
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A

(w)

N/23

5.	Fire Extinguisher:				
	A	Total numbers	55 nos.	80 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	Required	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	03 nos.	03 nos.	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	Provided	MR
9	Public Address System:		N/A	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per floor	03 nos.	03 nos.	MR
	C	Hose box	03 nos.	03 nos.	MR
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump each block	2 X 450 LPM	2 X 450 LPM	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

③

N/24

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	15,000 liters	15,000 liters	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/960 dated 25/11/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

No file is pending with me before disposal of this case.


22/10/2024

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

~~DY. CFO/NDZ~~

~~C.F.O.~~

~~Dir~~
24/10/24

~~29/10/2024~~

~~Director~~


~~2/11/24~~

~~ADLN~~

Sir. F.T Letter is put up for sign. Please

~~Director~~

~~1/11/24~~


01/11/2024