

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/2024/ 667

Dated 04/11/2024

FIRE SAFETY CERTIFICATE

Certified that the **National Sports Club of India** located at **Mathura Road, New Delhi** comprised of Ground + one upper floor, owned/occupied by **National Sports Club of India** was earlier granted FSC by this department vide letter No.F6/DFS/MS/2021/493 dated 11/10/2021. Now, the premises was re-inspected by the officers concerned of this department on 29/10/24 in the presence of **Sh. Naresh (Adm. Officer)** and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Assembly Building, Sub-Division D-3** with effect from 04/11/2024 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 04/11/2024 at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Joint Commissioner (Licensing) 1st Floor, Police Station Defence Colony, New Delhi Id no. 2024100915479 dated 15.10.2024.
3. The Manager/ Admin Officer, National Sports Club of India, Mathura Road, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration shall strictly be prohibited.

N/36

INSPECTION REPORT

1. Name & address of the building : National Sports Club of India at Mathura Road, New Delhi, Ground + one upper floor
 2. Type of occupancy : Group - D , Assembly occupancy
 3. Type of case:- : Renewal
 4. Details of previous NOC : F6/DFS/MS/2021/493 dated 11/10/2021.
 5. Fire safety directives No. : NA
 6. Date of inspection:- 29/10/24
 7. Name of the inspecting officer : Sh. Ravinder Singh, ADO (CC)
Sh. Rajinder Atwal, DO (CD)
Sh. S.K. Dua , DY. CFO (NDZ)
 8. Name & designation of officer
From the building side : Sh. Naresh (Adm. Officer)
 9. Year of construction : Old
 10. Applicant's letter No : 2024100915479 dated 15.10.2024.
- Old Case (renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	16 Mtr.	MR
	2) Gate width	06 mtr.	06 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	03 No.	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	1 mtr.	1.10 mtr.	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	NA	NA	NA
	E. Width of corridor	1 Mtr.	1.25 Mtr.	MR
	F. Door size	1 Mtr.	1.5 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	NA	NA	NA
	2) Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	24 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

6


6.	First-Aid Hose Reel			
	1) Total number at each floor	02 No.	provided	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm.	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	partially provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100 MM	MR
	2) Number of hydrants per floor	04/02	4/02	MR
	3) Hose box each floor	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	05	05	MR
	2) Hose box per floor	05	05	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	900 LPM	900 LPM	MR
	b) Head of main pump	40 mtr.	45 mtr.	MR
	c) Number of main pump	01	02	MR
	d) Jockey pump out put	280	280	MR
	e) Jockey pump head	40 mtr.	45 mtr.	MR
	f) Stand by pump output (Diesel Pump)	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	900 & 180 lpm	N/A
	b) Head of pump	N/A	40 m	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltr.	50,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR

	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC, Co2			MR


The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/2021/493 dated 11/10/2021, under rule 35(5) of the Delhi Fire Service rules 2010.


Signature of the Inspecting Officer


 Name :- S.K. Dua
 Designation :- Dy. CFO

Signature of the Inspecting Officer


 Name :- Rajinder Atwal
 Designation :- DO (CD)



Signature of the Inspecting Officer


 Name :- Ravinder Singh
 Designation :- ADO (CC)

C.F.O /

 01/11/2021
 Directed by

 11/11/21
 Delet

As approved, FSC put up for renewal and
 reinstated please.

 11/11/21

 11/11/21
 V. B. D. S.
 05/11/21