

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2024/SZ/362

Dated. 04./11./2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s Greenr Café** located at **Shop No 4, First & Second Floor**, Greater Kailash Part -1, Market, New Delhi 110048 in the building comprised of Basement, Ground plus Two upper floors owner/occupied by A Unit OF Elixmir Foods LLP was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2021/SZ/293 dated 18/10/2021. The restaurant premise was re-inspected by the officer concerned of this department on 25/10/2024 in the presence of Mr. Rajeev Ranjan and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Restaurant at 1st & 2nd Floor only) and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/11/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police, Lic /Branch, 1st Floor PS Defence Colony, New Delhi 110049 (Ref. MHA Portal 2024101015520 dated 10/10/2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL /NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Greenr Café (A Unit OF Elixmir Foods LLP) at N-4, First & Second Floor, Greater Kailash Part -1, Market, New Delhi 110048		
2	Type of Occupancy	Group-D Assembly Building. (Eating House)		
3	Building Comprised of	Basement, Ground plus 02 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2021/SZ/293 dated 18/10/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	26/10/2024		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Rajeev Ranjan		
10	Year of construction	1990	Restaurant at 1 st & 2 nd Floor only	
11	Applicant letter No.	MHA Portal 2024101015520 dated 10/10/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/ NBC-2016	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	08 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	Required	1.07 m & 1m	MR (old case)
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	02 exits	1 mtr each	MR (old case)
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	NA	N/A	N/A
	• Upper floors	12 ACPH	Provided in Kitchen	MR
5	Fire Extinguishers.			
	• Total numbers	Required	10 Nos	MR
	• Types	ABC/CO ₂	ABC-05 & CO ₂ -05	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor. 	One	Provided	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	Smoke type	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	Ground floor	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	NA	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	Provided	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground/ upper floors. 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	One	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	N/A	N/A
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Head of main pump. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of main pumps. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump output. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump head. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump house access. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	450 & 180 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of pump. 	35m	Provided	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw-off connection. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire Service Inlet. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Access to tank. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead tank capacity. 	10,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A

	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

Note-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2021/SZ/293 dated 18/10/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]
20/10

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (South)

[Handwritten Signature]
28/10/21

[Handwritten Signature]
CFO (MS)

[Handwritten Signature]
29/10/2021

[Handwritten Signature]
29/10/21

[Handwritten Signature]
DO/BCP

As approved, F.T. letter is put up for your signature pl.

[Handwritten Signature]
1/11/2021

[Handwritten Signature]
Director

[Handwritten Signature]
04/11/21