

No. F6/DFS/MS/WZ/EH/2024/364

Dated: 04/11/2024

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. Indus Flavour, (A unit of Arihant F & B) located at Shop No.SH-2F-11, 2<sup>nd</sup> floor, Pacific Mall, Subash Nagar, New Delhi-110018, is running at second floor in Pacific Mall Subash Nagar comprised of 02 Basement + Ground + 04 upper floors & projection room, owned/occupied by M/s. Indus Flavour (A unit of Arihant F & B). The premises was inspected by the officer concerned of this department on 24/10/2024 in the presence of Sh. Ashish Jain and observed that the management have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the premises is fit for occupancy class-"Assembly" Group-D (Restaurant at 2<sup>nd</sup> floor) **validity upto 31<sup>st</sup> March 2027** for a period of three years in accordance with Rule with 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, condition mentioned below.

Issued on.....04/11/2024.....at New Delhi by.

(Atul Garg)  
Director  
30/10  
25/10/2024

Copy to:

1. The Owner/occupier M/s. Indus Flavour, (A unit of Arihant F & B) located at Shop No.SH-2F-11 2<sup>nd</sup> floor Pacific Mall Subash Nagar, New Delhi-110018.
2. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. ([adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in).)
3. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. ([dhwestzone@gmail.com](mailto:dhwestzone@gmail.com))

**Following Fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building	Indus Flavour, (A unit of Arihant F & B) located at Shop No.811-2F-11, 2 <sup>nd</sup> floor, Pacific Mall, Subash Nagar, New Delhi-110018.
2. Type of Occupancy	Assembly
3. Type of Case	New
4. Details of previous NOC	Nil
5. Fire Safety directives letter No	NBC Part - IV
6. Date of inspection	24/10/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Ashish Jain
9. Year of Construction	2010 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2024100915472 dated 09/10/2024

**The Said Restaurant is running at second floor in Pacific Mall Comprised of 02 Basement + Ground + 04 upper floors & projection room, was issued FSC by this department vide letter No. F6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BDL/NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	12 m	Provided	MR
	• Gate width	4.5m	On Main Road	MR
	• Width of internal road	06 m	Provided	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits (Common with the Mall)</b>			
	a. Number of staircases			
	• Upper Floors	2	Provided	MR
	• Basements	NA	NA	Running at 2 <sup>nd</sup> floor
	b. Width of staircases			
	• Upper Floors	1.5 mtr each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	Required	Provided	MR
	g. Door Size	1.5 m X 2	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	04 Nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6		First-Aid Hose Reels. Common with Mall		
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7		Automatic fire detection and alarming system.		
	• Type of detectors	NA	Smoke & Heat Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8		MOEFA		
		Required	Provided	MR
9		Public Address System.		
		NA	Provided	NA
10		Automatic Sprinkler System. Common with Mall		
	• Basement	NA	Provided	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11		Internal Hydrants Common with Mall		
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12		Yard Hydrants.		
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13		Pumping Arrangements. Common With Mall		
	• Ground Level			
	➤ Discharge of main Pump	NA	Common With Mall	NA
	➤ Head of Main pump	NA	Common With Mall	NA
	➤ Number of main pumps	NA	Common With Mall	NA
	➤ Jockey Pump out put	NA	Common With Mall	NA
	➤ Jockey pump head	NA	Common With Mall	NA
	➤ Standby Pump out put	NA	Common With Mall	NA
	➤ Standby Pump Head	NA	Common With Mall	NA
	➤ Auto Starting/ Manual stopping	NA	Common With Mall	NA
	➤ Pump House Access	NA	Common With Mall	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common With Mall	MR
	➤ Head of the pump	40 m	Common With Mall	MR
	➤ Power Supply	Required	Common With Mall	MR
	➤ Auto Starting of pump	Required	Common With Mall	MR
14		Captive Water Storage for fire fighting. Common With Mall		
	• Underground tank capacity	NA	2,00,000 ltrs Provided	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20,000 ltrs	30,000 ltrs Provided	MR
15		Exit Signage.		
		Required	Provided	MR

Provision of Lifts.				
16	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18 Refuge Area.				
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19 Fire Control Room				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Earlier all the shortcomings were issued by this department have been complied by the restaurant management.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Received  
on 25/10/2024

~~Dy CEO (w/12)~~

~~SSP~~  
25/10/2024

DCFO/446-MNA  
Dated 30/10/24

~~dy~~  
30/10/2024

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

~~efo/~~  
at n room

322/ADO/MN  
25/10/2024.

~~Director~~  
11/11/24

~~MSL~~

Uploaded  
04/11/24

~~DZ~~